

Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration

API 510
TENTH EDITION, MAY 2014

ADDENDUM 1, MAY 2017
ADDENDUM 2, MARCH 2018



AMERICAN PETROLEUM INSTITUTE

This is a preview. [Click here to purchase the full publication.](#)

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this Standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the Standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this Standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2014 American Petroleum Institute

[This is a preview. Click here to purchase the full publication.](#)

Date of Issue: March 2018

Affected Publication: API 510, *Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration*, Tenth Edition, May 2014

Addendum 2

Page v (Table of Contents): Changed title in the entry for Section 6.7 to the following:

6.7 Deferral of Inspections, Examinations, and Tests 39

Page 6: Added “deferral” term and definition:

3.1.16

deferral

An approved and documented postponement of an inspection, test, or examination. See 6.7.

Page 6: Added “due date” term and definition:

3.1.19

due date

The date established by the owner-user and in accordance with this code, whereby an inspection, test, examination, or inspection recommendation falls due or is to be completed. The date may be established by rule-based inspection methodologies (e.g. fixed intervals, retirement half-life interval, retirement date), risk-based methodologies (e.g. RBI target date), fitness-for-service analysis results, owner-user inspection agency practices/procedures/guidelines, or any combination thereof.

Page 8: Deleted “inspection deferral” definition.

Page 16: Section 4.3 shall read:

All repairs and alterations shall be performed by a qualified repair organization. The repair organization is responsible to the owner/user and shall provide the materials, equipment, QC, and workmanship that is necessary to maintain and repair the vessel or pressure-relieving device in accordance with the requirements of this inspection code. See definition of a repair organization in 3.1.63.

Page 38: Section 6.6.1 shall read:

Pressure-relieving devices shall be tested and repaired by a repair organization qualified and experienced in relief valve maintenance per definitions in 3.1.63. Pressure-relieving devices should be inspected, tested, and maintained in accordance with API 576.

Page 39: Section 6.7 shall read:

6.7 Deferral of Inspections, Tests, and Examinations

Inspections, tests, or examinations for pressure vessels and associated pressure-relieving devices that cannot be completed by their due date may be deferred for a specified period, subject to the requirements in the following sub-sections.

Pressure vessels or pressure-relieving devices that are operated beyond the due date without a valid deferral in accordance with these requirements are not permitted by this code. Deferrals should be the occasional exception, not a frequent occurrence. All deferrals shall be documented. Pressure vessels or pressure-relieving devices that were granted a deferral can be operated to the new due date without being considered overdue for the deferred inspections, tests, or examinations.

6.7.1 Simplified Deferral

A simplified short-term deferral may be approved by the owner-user if all of the following conditions are met:

- a) The current due date for the inspection, test, or examination has not been previously deferred.
- b) The proposed new due date would not increase the current inspection/servicing interval or due date by more than 10 % or six months, whichever is less.
- c) A review of the current operating conditions, as well as the pressure vessel or pressure-relieving device history, has been completed, with results that support a short-term/one-time deferral.
- d) The deferral request has the consent of the inspector representing or employed by the owner-user and an appropriate operations management representative(s).
- e) Updates to the pressure vessel or pressure-relieving device records with deferral documentation are complete before it is operated beyond the original due date.

6.7.2 Deferral

Deferral requests not meeting the conditions of a simplified deferral shall follow a documented deferral procedure/process that includes all of the following minimum requirements:

- a) Perform a documented risk assessment or update an existing RBI assessment to determine if the proposed deferral date would increase risk above acceptable risk threshold levels as defined by the owner-user. The risk assessment may include any of the following elements as deemed necessary by the owner/user.
 - fitness-for-service analysis results;
 - consequence of failure;
 - applicable damage mechanism susceptibilities and rates of degradation;
 - calculated remaining life;
 - historical conditions/findings from inspections, tests, and examinations and their technical significance;
 - extent and/or probability of detection (i.e. effectiveness) of previous inspections, tests, or examinations, as well as the amount of time that has elapsed since they were last performed;

- considerations for any previous changes to inspection or test intervals (e.g. reductions in interval due to deteriorating conditions);
 - disposition(s) of any previous requests for deferral on the same pressure vessel or pressure-relieving device;
 - historical conditions/findings for pressure vessels or pressure-relieving devices in similar service if available
- b) Determine if the deferral requires the implementation of, or modification to, existing integrity operating windows or operating process control limits.
- c) Review the current inspection plan to determine if modifications are needed to support the deferral.
- d) Obtain the consent and approval of appropriate pressure vessel personnel, including the inspector representing or employed by the owner-user and appropriate operations management representative(s).
- e) Updates to the pressure vessel or pressure-relieving device records with deferral documentation are complete before it is operated beyond the original due date.

Page numbers in the Table of Contents have been updated to account for the above changes.

Foreword

In December 1931, API and the American Society of Mechanical Engineers (ASME) created the Joint API/ASME Committee on Unfired Pressure Vessels. This committee was created to formulate and prepare for publication a code for safe practices in the design, construction, inspection, and repair of pressure vessels to be used in the petroleum industry. Entitled *API/ASME Code for Unfired Pressure Vessels for Petroleum Liquids and Gases* (commonly called the *API/ASME Code for Unfired Pressure Vessels* or *API/ASME Code*), the First Edition of the *API/ASME Code* was approved for publication in 1934. From its inception, the *API/ASME Code* contained Section I, which covered recommended practices for vessel inspection and repair and for establishing allowable working pressures for vessels in service. Section I recognized and afforded well-founded bases for handling various problems associated with the inspection and rating of vessels subject to corrosion. Although the provisions of Section I (like other parts of the *API/ASME Code*) were originally intended for pressure vessels installed in the plants of the petroleum industry, especially those vessels containing petroleum gases and liquids, these provisions were actually considered to be applicable to pressure vessels in most services. ASME's Boiler and Pressure Vessel Committee adopted substantially identical provisions and published them as a nonmandatory appendix in the 1950, 1952, 1956, and 1959 editions of Section VIII of the *ASME Boiler and Pressure Vessel Code*.

After the *API/ASME Code* was discontinued in 1956, a demand arose for the issuance of Section I as a separate publication, applicable not only to vessels built in accordance with any edition of the *API/ASME Code* but also to vessels built in accordance with any edition of Section VIII of the *API/ASME Code*. Such a publication appeared to be necessary to assure industry that the trend toward uniform maintenance and inspection practices afforded by Section I of the *API/ASME Code* would be preserved. API 510, first published in 1958, is intended to satisfy this need.

The procedures in Section I of the 1951 edition of the *API/ASME Code*, as amended by the March 16, 1954 addendum, have been updated and revised in API 510. Section I of the *API/ASME Code* contained references to certain design or construction provisions, so these references have been changed to refer to provisions in the *API/ASME Code*. Since the release of the 1960 edition of the National Board Inspection Code, elements of the *API/ASME Code* have also been carried by the National Board Inspection Code.

It is the intent of API to keep this publication up to date. All pressure vessel owners and operators are invited to report their experiences in the inspection and repair of pressure vessels whenever such experiences may suggest a need for revising or expanding the practices set forth in API 510.

This edition of API 510 supersedes all previous editions of API 510. Each edition, revision, or addendum to this API code may be used beginning with the date of issuance shown on the cover page for that edition, revision, or addendum. Each edition, revision, or addendum to this API code becomes effective six months after the date of issuance for equipment that is rerated, reconstructed, relocated, repaired, modified (altered), inspected, and tested per this code. During the six-month time between the date of issuance of the edition, revision, or addendum and the effective date, the user shall specify to which edition, revision, or addendum the equipment is to be rerated, reconstructed, relocated, repaired, modified (altered), inspected, and tested.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, "shall" denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, "should" denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which

this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the Director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

	Page
1 Scope	1
1.1 General Application	1
1.2 Specific Applications	2
1.3 Recognized Technical Concepts	2
2 Normative References	2
3 Terms, Definitions, Acronyms, and Abbreviations	4
3.1 Terms and Definitions	4
3.2 Acronyms and Abbreviations	13
4 Owner/User Inspections Organization	14
4.1 Owner/User Organization Responsibilities	14
4.2 Engineer	16
4.3 Repair Organization	16
4.4 Inspector	16
4.5 Examiners	16
4.6 Other Personnel	16
4.7 Inspection Organization Audits	17
5 Inspection, Examination, and Pressure Testing Practices	17
5.1 Inspection Plans	17
5.2 Risk-Based Inspection (RBI)	19
5.3 Preparation for Inspection	20
5.4 Inspection for Different Types of Damage Mechanisms and Failure Modes	21
5.5 Types of Inspection and Surveillance for Pressure Vessels	23
5.6 Condition Monitoring Locations (CMLs)	27
5.7 Condition Monitoring Methods	29
5.8 Pressure Testing	31
5.9 Material Verification and Traceability	33
5.10 Inspection of In-service Welds	33
5.11 Inspection and Repair of Flanged Joints	34
5.12 Inspection of Shell and Tube Heat Exchangers	34
6 Interval/Frequency and Extent of Inspection	34
6.1 General	34
6.2 Inspection During Installation and Service Changes	35
6.3 RBI	35
6.4 External Inspection	36
6.5 Internal, On-stream, and Thickness Measurement Inspections	36
6.6 Pressure-relieving Devices	38
6.7 Deferral of Inspections, Examinations, and Tests	39
6.8 Deferral of Inspection Repair Recommendation Due Dates	40
6.9 Review of Inspection Repair Recommendations	41
7 Inspection Data Evaluation, Analysis, and Recording	41
7.1 Corrosion Rate Determination	41
7.2 Remaining Life Calculations	42

Contents

	Page
7.3 Maximum Allowable Working Pressure (MAWP) Determination	42
7.4 FFS Analysis of Corroded Regions	43
7.5 FFS Evaluations	45
7.6 Required Thickness Determination	46
7.7 Evaluation of Existing Equipment with Minimal Documentation	46
7.8 Reports and Records	47
8 Repairs, Alterations, and Rerating of Pressure Vessels and Pressure-relieving Devices	48
8.1 Repairs and Alterations	48
8.2 Rerating	57
9 Alternative Rules for E&P Pressure Vessels	59
9.1 Scope and Specific Exemptions	59
9.2 Definitions	59
9.3 Inspection Program	60
9.4 Pressure Test	64
9.5 Safety Relief Devices	64
9.6 Records	64
Annex A (normative) Code Exemptions	65
Annex B (normative) Inspector Certification	67
Annex C (informative) Sample Pressure Vessel Inspection Record	69
Annex D (informative) Sample Repair, Alteration, or Rerating of Pressure Vessel Form	71
Annex E (informative) Technical Inquiries	73
Figures	
8.1 Rerating Vessels Using the Latest Edition or Addendum of the ASME Code Allowable Stresses	58
8.2 Sample Additional Nameplate	59
Tables	
7.1 Values of Spherical Radius Factor K_1	46
8.1 Qualification Limits for Base Metal and Weld Deposit Thicknesses for the CDW Method	56