

ANSI/AWWA C516-21

(Revision of ANSI/AWWA C516-14)

AWWA Standard

Large-Diameter Rubber-Seated Butterfly Valves, Sizes 78 In. (2,000 mm) and Larger

Effective date: July 1, 2021.

First edition approved by Board of Directors Feb. 12, 2006.

This edition approved March 30, 2021.

Approved by American National Standards Institute March 24, 2021.



American Water Works
Association



This is a preview. [Click here to purchase the full publication.](#)


AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.



ISBN-13, print: 978-1-64717-051-6

ISBN-13, electronic: 978-1-61300-588-0

DOI: 10.12999/AWWA.C516.21

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

Copyright © 2021 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Subcommittee for Large-Diameter Butterfly Valves that reviewed this standard had the following personnel at the time of approval:

John Holstrom, *Chair*

J.W. Green, Lockwood, Andrews & Newman, Oakbrook Terrace, Ill.
R.A. Ward, Dufresne & Associates PC, Windsor, Vt.
A. Abouelleil, Henry Pratt Company, Aurora, Ill.
J.V. Ballun, Val-Matic Valve and Manufacturing Corporation, Addison, Ill.
H. Herold, VAG, Mannheim, Germany
D.E. Douro, Olson Technologies Inc., Allentown, Pa.
J.R. Holstrom, Val-Matic Valve and Manufacturing Corporation, Elmhurst, Ill.
J.D. Grant, DeZURIK/APCO/HILTON, Sartell, Minn.
B.J. Lewis, Crispin Multiplex Mfg. Co., Berwick, Pa.
A.W. Libke, DeZURIK/APCO/HILTON, Sartell, Minn.
T. Martin, Adams Valves Inc., Houston, Texas
J.H. Wilber, American AVK, Littleton, Colo.
S. Carpenter, San Diego Water, Escondido, Calif.
V.Q. Le, Los Angeles Water and Power, Los Angeles, Calif.
P. Ries, Denver Water Department, Denver, Colo.
S.Y. Tung, City of Houston, Houston, Texas

The AWWA Standards Committee on Butterfly Valves, which reviewed and approved this standard, had the following personnel at the time of approval:

Mark MacConnell, *Chair*

General Interest Members

A. Ali, ADA Consulting, Surrey, B.C., Canada
M.D. Bennett, MWH, Cleveland, Ohio
B.E. Bosserman, Engineering Consultants, Mission Viejo, Calif.
J. Hebenstreit, UL LLC, Northbrook, Ill.
F. Hinker, Santa Rosa, N. Mex.
X.J. Iriaes (*liaison, nonvoting*), Standards Council Liaison, Walnut Creek, Calif.
M.C. Johnson, Utah State University, Water Research Laboratory, Logan, Utah

J.N. Nakashima, Lockwood, Andrews & Newnam, Inc., Oakbrook, Texas
T.J. McCandless (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
U. Sant, AECOM, Dallas, Texas
R.A. Ward, Dufresne & Associates PC, Windsor, Vt.

Producer Members

S. Allen, Bray Valve, Jonesboro, Ark.
M. Bissauge, VAHN-TECH International Inc., Toronto, Ont. Canada
A.G. Granzow, NIBCO, Inc., Elkhart, Ind.
T.A. Hartman, Hartman Valve Corporation, St. Louis, Mo.
H. Heribert, VAG, Mannheim, Germany
J.R. Holstrom, Val-Matic Valve and Manufacturing Corporation, Elmhurst, Ill.
J.D. Grant (*alternate*), DeZURIK/APCO/HILTON, Sartell, Minn.
K.R. Graeff (*alternate*), Rodney Hunt Company, Orange, Mass.
K. Johnson, M&H Valve Company, Anniston, Ala.
A.W. Libke, DeZURIK/APCO/HILTON, Sartell, Minn.
J. Wilber, American AVK Company, Littleton, Colo.

User Members

L. Adams, United States Bureau of Reclamation, Denver, Colo.
S. Carpenter, San Diego County Water Authority, Escondido, Calif.
D.W. Coppes, Massachusetts Water Resources Authority, Chelsea, Mass.
S. Hattan, Tarrant Regional Water District, Ft. Worth, Texas
R. Kilborn, City of Chandler, Chandler, Ariz.
V.Q. Le, Los Angeles Water and Power, Los Angeles, Calif.
M. MacConnell, Burnaby, B.C., Canada
P.J. Ries, Denver Water Department, Denver, Colo.
S.Y. Tung, City of Houston, Houston, Texas

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>		V	Comments xix
I	Introduction..... vii		
I.A	Background..... vii	<i>Standard</i>	
I.B	History..... vii	1 General	
I.C	Acceptance vii	1.1	Scope 1
II	Special Issues ix	1.2	Purpose 2
II.A	General ix	1.3	Application 2
II.B	Buried Valves..... ix	2 References	2
II.C	Advisory Information on Product Applications x	3 Definitions	4
II.D	Advisory Information on Scheduling Requirements xi	4 Requirements	
II.E	Valve Discs and Piping Design xii	4.1	Data to Be Provided by the Manufacturer 7
II.F	Effects of Manual or Power Actuator Stroke Time..... xiii	4.2	Materials. 8
II.G	Chlorine and Chloramine Degradation of Elastomers xiii	4.3	General Design 9
II.H	Bolting Gray Cast Iron Flanges to Steel Flanges..... xiii	4.4	Valve Actuators..... 18
II.I	Permeation by Organic Solvents or Petroleum Products. xiv	4.5	Welding and Fabrication 23
II.J	Advisory Information on Valve Design..... xiv	4.6	Coatings..... 24
III	Use of This Standard xv	5 Verification	
III.A	Purchaser Options and Alternatives xv	5.1	Shop Tests 25
III.B	Modification to Standard xviii	5.2	Proof-of-Design Tests 27
IV	Major Revisions..... xviii	5.3	Actuator Proof-of-Design Testing..... 29
		5.4	Nonconformance 30
		6 Delivery	
		6.1	Marking 30
		6.2	Shipping..... 30

SEC.	PAGE	SEC.	PAGE
<i>Appendices</i>			
A	Installation, Operation, and Maintenance of Large-Diameter Butterfly Valves	A.7	Operation
	33	A.8	Maintenance
			38
<i>Tables</i>			
A.1	General	1	Laying Length Ranges for Flanged Valves.....
	33		9
A.2	Unloading	2	Actuator Application Factors (AF) ...
	33		20
A.3	Storage	3	Valve Test Cycles Required
	33		27
A.4	Inspection Prior to Installation	4	Prototype Actuator Proof-of-Design Test Cycles Required
	34		28
A.5	Installation		
	35		
A.6	Field Testing		
	37		

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C516.

I. Introduction.

I.A. *Background.* Large-diameter butterfly valves are generally used for pipelines carrying water and gases in power generation facilities, water treatment plants, and major water supply and distribution lines. Butterfly valves are isolation and flow-control devices that provide tight shutoff, are relatively easy to operate, even with moderate pressure drops across the valves, and require relatively little space for installation.

I.B. *History.* The need for standardization of butterfly valves was recognized by the American Water Works Association (AWWA) with the adoption of AWWA C504 for Rubber-Seated Butterfly Valves in 1954. This companion standard was developed by the AWWA Standards Committee on Feb. 12, 2006, to meet the need for large-diameter valves in the waterworks industry. The second edition of ANSI/AWWA C516 was approved by the AWWA Board of Directors on June 8, 2014. This edition was approved on March 30, 2021.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). AWWA and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.

* Persons outside the United States should contact the appropriate authority having jurisdiction.