

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.

TENTH EDITION



**EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
25 NORTH BROADWAY, TARRYTOWN, NY 10591 USA
RICHARD C. BYRNE, SECRETARY
TEL: 1-914-332-0040
E-MAIL: ejma@ejma.org
www.ejma.org**

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION
FOREWORD

Since 1958, when the Expansion Joint Manufacturer's Association (EJMA®) first published these Standards, continuing technological improvements in the application and design of Expansion Joints have been reported through the cooperative efforts of its association members by expanding the scope and content of this publication. Founded three years earlier in 1955, the Expansion Joint Manufacturer's Association began with a group of companies experienced in the application, design, and fabrication of Expansion Joints. The first EJMA® Standard edition was, of necessity, somewhat brief and covered only applications involving axial movement. But as research and extensive testing results were catalogued, more detailed design data has been included in the EJMA® Standard. The EJMA® Standards are intended for application to metallic bellows expansion joints having only the convolution shapes shown in the Standards and having convolution welds only in the meridional direction with the exception of the bellows attachment welds.

The EJMA® Technical Committee is dedicated to continuously improving the utility and technical content of the Standards. Suggestions and comments from industry users are welcomed and should be forwarded to the Secretary of this Association in writing.

It is important to note that the EJMA® Standard is a trade association document containing recommendations for application of expansion joint products and in-depth technical information for use in designing expansion joint products. It is not a manufacturing standard or a quality assurance document. The type of non-destructive examination and the extent of quality assurance testing to be applied to given product should be addressed by other documents such as the ASME B31.3 Piping Code, the ASME Pressure Vessel Code, or another user-provided specification. The Standard does not limit or dictate the manufacturing process to be used for construction of expansion joints, nor does it establish specific engineering requirements deemed necessary for the safe application, design, and manufacture of Expansion Joints. If there is a strong preference for a certain type of manufacturing process, the user should provide this information. Industry users are cautioned that these Standards should not be considered as a design handbook, and must not replace sound engineering judgment, education, and experience.

As of this writing, the EJMA® Standard thoroughly covers the design of expansion joint bellows elements. However, the Standard does not cover the design of hardware associated with restraint of pressure thrust. Pressure thrust restraint hardware is as important as the bellows element in the design and fabrication of an expansion joint assembly. Users are strongly advised to obtain documented design results for bellows elements and pressure thrust restraint hardware for any critical application.

NO WARRANTY EXPRESSED OR IMPLIED

The engineering Standards herein are recommended by the Expansion Joint Manufacturers Association, Inc. to assist users, engineers, architects and others who specify, design and install Expansion Joints in piping systems to obtain the most efficient service from Expansion Joint installations. These Standards are based upon sound engineering principles, research and field experience in the manufacture, design, installation and use of Expansion Joints. These Standards may be subject to revision as further investigation or experience may show is necessary or desirable. Utilization of these Standards remains entirely optional. Nothing herein shall constitute a warranty of any kind, expressed or implied. Accordingly, all warranties of whatever nature, expressed or implied, are herewith specifically disclaimed and disavowed.

**Copyright © 1958, 1962, 1969, 1975, 1976, 1980, 1985, 1993, 1998,
2003, 2005, 2008, 2009, 2010, 2011, 2015**

EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.

All rights reserved. This book or any part thereof may not be reproduced in any form without written permission of the Expansion Joint Manufacturers Association, Inc.

The specification sheets constituting Appendix A are not covered by any copyright restrictions and may be freely reproduced and utilized by purchasers of this Standards manual.

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

MEMBERSHIP LIST

EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.

Aerosun-Tola Expansion Joint Co. Ltd. – Nanjing, China
American BOA, Inc. - Cumming, GA
Badger Industries, Inc. - Zelienople, PA
EagleBurgmann EJS - Lakeside, CA
Flexider - Torino, Italy
HKR Co., Ltd – Kyunggi-Do, S. Korea
Hyspan Precision Products, Inc. - Chula Vista, CA
Idrosapiens, S.r.l - Leini (Torino), Italy
Microflex - Ormond Beach, FL
Senior Flexonics, Inc., Pathway Division – New Braunfels, TX and Lewiston, ME
Teadit – Rio de Janeiro, Brazil
Teddington Engineered Solutions Ltd. – Llanelli, UK
U.S. Bellows, Inc. – Houston, TX
Witzenmann, GmbH – Pforzheim, Germany

CURRENT TECHNICAL COMMITTEE MEMBERS

EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.

Yuhua Niu - Aerosun-Tola Expansion Joint Co. Ltd.
Patrick Vainio - American BOA, Inc.
Jack Hanna - Badger Industries, Inc.
Farhad Kermani - EagleBurgmann EJS
Avio Giorio - Flexider S.r.l. - Torino, Italy
Jingeun Kim - HKR Co., Ltd
Zoltan Takarich - Hyspan Precision Products, Inc.
Attilio Pietrafesa - Idrosapiens, S.r.l
Jeff DePiero - Microflex
Eric Davis - Senior Flexonics, Inc., Pathway Division
José Veiga- Teadit
Steven Thomas - Teddington Engineered Solutions Ltd.
Scott Stelmar - U.S. Bellows, Inc.
Peter Berger - Witzenmann, GmbH

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

This page intentionally blank.

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

CONTENTS

Section	Page
Foreword	ii
Membership of EJMA.	iii
Current Technical Committee Members	iii
 SECTION 1 – SCOPE, DEFINITIONS, AND NOMENCLATURE	
1.1 Scope	1-1
1.2 Definition of Terms.....	1-1
1.3 Nomenclature	1-6
 SECTION 2 – SELECTION AND APPLICATIONS	
2.1 Selection of Expansion Joints	2-1
2.2 Selection for Axial Movement Only	2-2
2.3 Selection for Lateral Deflection, Angular Rotation, and Combined Movements	2-5
2.4 Applications Using Single Expansion Joints	2-6
2.5 Applications Using Universal Expansion Joints	2-8
2.6 Applications Using Pressure Balanced Expansion Joints	2-12
2.7 Applications Using Hinged Expansion Joints	2-15
2.8 Calculation of Angular Rotation in a 3 Hinge Piping System	2-20
2.9 Applications Using Gimbal Expansion Joints	2-22
2.10 Anchor, Guide, and Support Requirements	2-23
 SECTION 3 – SAFETY RECOMMENDATIONS FOR PIPING SYSTEMS CONTAINING BELLOWS EXPANSION JOINTS	
3.1 Design Specification	3-1
3.2 Expansion Joint Design	3-3
3.3 Expansion Joint Manufacturing Quality	3-3
3.4 Installation	3-3
3.5 Post Installation Inspection Prior to System Pressure Test	3-4
3.6 Inspection During and Immediately After System Pressure Tests	3-4
3.7 Periodic In-Service Inspection	3-5
 SECTION 4 – CIRCULAR EXPANSION JOINT DESIGN	
4.1 Movement Equations.....	4-1
4.2 Combining Movements	4-2
4.3 Movement Range	4-3
4.4 Universal Circular Expansion Joint Movements	4-5
4.5 Cold Springing of Circular Expansion Joints	4-5
4.5.1 Force Reduction	4-5
4.5.2 Stability	4-5
4.5.3 Component Clearances	4-6
4.6 Forces and Moments	4-6
4.6.1 Force and Moment Calculation	4-6
4.6.2 Restraint Hardware Force and Moment Calculations	4-7
4.7 Maximum Axial Compression Based On Instability	4-10

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

SECTION 4 – CIRCULAR EXPANSION JOINT DESIGN (continued)

4.8	Expansion Joint Flange Loading Considerations	4-10
4.9	Vibration	4-11
4.9.1	Single Bellows	4-11
4.9.2	Dual Bellows (Universal Expansion Joint)	4-13
4.9.3	Internal Sleeves - Circular Expansion Joints	4-13.1
4.10	Internal Sleeves – Circular Expansion Joints	4-14
4.10.1	Criteria for Determining the Need for Internal Sleeves	4-14
4.10.2	Limits for Flow Velocities	4-14
4.10.3	Design Recommendations for Internal Sleeves	4-16
4.11	External Covers – Circular Expansion Joints.....	4-17
4.12	Bellows Design	4-18
4.12.1	Parameters and Criteria Affecting Bellows Design	4-19
4.12.1.1	Unreinforced Bellows	4-19
4.12.1.2	Reinforced Bellows	4-19
4.12.1.3	Internal Pressure Capacity	4-20
4.12.1.4	Deflection Stress	4-20
4.12.1.5	Fatigue Life Expectancy	4-21
4.12.1.6	Bellows Stability	4-23
4.12.1.7	Bellows Spring Rate	4-26
4.12.1.8	Correlation Testing	4-27
4.12.1.9	Bellows Heat Treatment	4-27
4.13	Design Equations	4-28
4.13.1	Design Equations for Unreinforced Bellows	4-28
4.13.2	Design Equations for Reinforced Bellows	4-30
4.13.3	Design Equations for Toroidal Bellows	4-32
4.13.4	Bellows Torsion – Unreinforced/Reinforced Bellows	4-33
4.14	Benchmark Calculations	4-34
4.15	Effect of External Pressure	4-42

SECTION 5 - RECTANGULAR EXPANSION JOINT DESIGN

5.1	Movement Equations	5-1
5.2	Combining Movements	5-4
5.3	Movement Range	5-4
5.4	Force and Moment Calculations	5-5
5.5	Design Equations	5-6

SECTION 6 – QUALITY ASSURANCE AND BELLOWS FORMING METHODS

6.1	General	6-1
6.2	Authority and Responsibility	6-1
6.3	Quality Assurance Organization	6-1
6.4	Drawings, Design Calculations, and Specification Control	6-1
6.5	Materials and Materials Control	6-2
6.6	Manufacturing Process Control	6-2
6.7	In-Process Inspection and Examination Program	6-2
6.8	Measuring and Test Equipment Control	6-3
6.9	Material Non-conformance Control	6-3
6.10	Corrective Action (Supplies and Services)	6-3
6.11	Welding	6-3

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

SECTION 6 – QUALITY ASSURANCE AND BELLOWS FORMING METHODS (continued)

6.12	Heat Treatment	6-3
6.13	Packaging, Preservation, Shipping and Storage	6-3
6.14	Customer Quality Assurance Audits	6-4
6.15	Records Retention	6-4
6.16	Methods of Forming Metal Bellows	6-4
6.16.1	Elastomeric Forming	6-4
6.16.2	Expansion (Expanding Mandrel) Forming	6-5
6.16.3	Hydraulic Forming	6-5
6.16.4	Pneumatic Tube Forming	6-6
6.16.5	Rolled Convoluted Sheet	6-6
6.16.6	Roll Forming	6-7
6.16.7	Rolled Ring	6-7
6.16.8	Press-Brake Forming	6-8
6.16.9	Combined Forming	6-8
6.17	Fabrication Tolerances	6-9

SECTION 7 – EXAMINATION AND TESTING

7.1	Non-destructive Examination	7-1
7.1.1	Radiographic Examination	7-1
7.1.2	Liquid Penetrant Examination	7-1
7.1.3	Fluorescent Penetrant Examination	7-2
7.1.4	Magnetic Particle Examination	7-2
7.1.5	Ultrasonic Examination	7-2
7.1.6	Halogen Leak Examination	7-2
7.1.7	Mass Spectrometer Examination	7-3
7.1.8	Air Jet Leak Examination	7-3
7.2	Non-destructive Testing	7-3
7.2.1	Pressure Testing	7-3
7.3	Destructive Testing	7-4
7.3.1	Fatigue Life Testing	7-4
7.3.2	Squirm Testing	7-4
7.3.3	Meridional Yield-Rupture Testing	7-5

SECTION 8 – SHIPPING AND INSTALLATION

8.1	Shipping Tags	8-1
8.2	Shipping Devices	8-1
8.3	Installation	8-2
8.4	Gaskets	8-2
8.5	Recommended Installation Instructions	8-3

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION
SECTION 9 – FEATURES, ACCESSORIES, AND MATERIALS

9.1	Multi-Ply Bellows	9-1
9.1.1	Multi-Ply Construction with the Same Total Thickness as a Single Ply Construction	9-1
9.1.1.1	Pressure Capacity	9-1
9.1.1.2	Fatigue Life	9-1
9.1.1.3	Spring Forces	9-1
9.1.1.4	Bellows Stability	9-1
9.1.2	Multi-Ply Construction with the Same Thickness for Each Ply as a Single Ply Construction	9-1
9.1.2.1	Pressure Capacity	9-1
9.1.2.2	Fatigue Life	9-1
9.1.2.3	Spring Forces	9-1
9.1.2.4	Bellows Stability	9-1
9.1.3	Multi-Ply Construction with Greater Thickness for Each Ply Than for Single Ply Construction ...	9-2
9.1.3.1	Pressure Capacity	9-2
9.1.3.2	Fatigue Life	9-2
9.1.3.3	Spring Forces	9-2
9.1.3.4	Bellows Stability	9-2
9.1.4	Multiple Material Usage	9-2
9.1.5	Redundant Ply Construction with the Same Thickness for Each Ply as a Single Ply Construction	9-3
9.1.5.1	Pressure Capacity	9-3
9.1.5.2	Fatigue Life	9-3
9.1.5.3	Spring Forces	9-3
9.1.5.4	Bellows Stability	9-3
9.1.5.5	Monitored Ply Bellows	9-3
9.2	Tie Rods, Hinges and Similar Accessories	9-4
9.2.1	Forces and Loads	9-4
9.2.2	Methods of Attachment	9-4
9.2.3	Design Consideration	9-4
9.2.3.1	Tie Rods, Hinges, and Gimbals	9-4
9.2.3.2	Attachments to Piping	9-5
9.2.3.3	Component Design Stress Limits	9-5
9.2.3.4	References	9-12
9.3	Flanges	9-13
9.4	Corrosion	9-14

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION
APPENDICES

Appendix A	Standard Expansion Joint Specification Sheets	
Appendix B	Key to Symbols Used	
Appendix C	Circular and Rectangular Movement, Force and Moment Equations	
Appendix D	Conversion Factors and References	
Appendix E	Preparation of Technical Inquiries	
Appendix F	Bellows Fatigue Test Requirements	
Appendix G	Bellows High Temperature Cycle Life	
Appendix H	Angular Rotation about One End	
Appendix I	Tabulated Values for C_p , C_f , C_d , B_1 , B_2 , and B_3	
Appendix J	Examples	
Example 1	Single Expansion Joint subjected to axial movement.....	J-2
Example 2	Single Expansion Joint subjected to axial and lateral movement	J-6
Example 3	Single Expansion Joint with tie rods subjected to axial and lateral movement	J-12
Example 4	Tied Universal Expansion Joint subjected to lateral movement in two planes	J-18
Example 5	Universal pressure balanced Expansion Joint located between two pieces of equipment with movements at end points	J-26
Example 6	Single Expansion Joint, attached to vessel nozzle, subjected to axial and lateral movement .	J-36
Example 7	Calculation of Angular Rotation in a 3 hinge piping system	J-44
Example 8	Three (3) hinge Expansion Joint system	J-48
Example 9	Bellows Equivalent Movement per Convolution	J-54
Example 10	Rectangular Expansion Joint Movements.....	J-68
Example 11	Calculation for a Straight Run of Pipe Containing an Axial Expansion Joint	J-76

TABLES

Table I	Recommended Identification Data Required for Bellows subjected to Destructive Tests.....	7-6
Table II	Component Design Stress Limits	9-6
Table III	Shape Factors	9-8
Table IV	Thermal Expansion of Pipe in Inches per 100 Feet	D-16
Table V	Moduli of Elasticity of Commonly Used Bellows Materials	D-20

STANDARDS OF THE EXPANSION JOINT MANUFACTURERS ASSOCIATION, INC.
TENTH EDITION

This page intentionally blank.

SECTION 1 – SCOPE, DEFINITIONS, AND NOMENCLATURE

1.1 SCOPE

The EJMA® Standards are only intended for application to metallic bellows expansion joints.

1.2 DEFINITION OF TERMS

The Expansion Joint Manufacturers Association, Inc. has adopted the following definitions of Expansion Joint components and related equipment.

ANGULAR ROTATION

The displacement of the longitudinal axis of the Expansion Joint from its initial straight line position into a circular arc. Angular rotation is occasionally referred to as "rotational movement." This is not torsional rotation which is described further in this section.

AXIAL COMPRESSION

The dimensional shortening of an Expansion Joint along its longitudinal axis. Axial compression has been referred to as axial movement, traverse or compression.

AXIAL EXTENSION

The dimensional lengthening of an Expansion Joint along its longitudinal axis. Axial extension has been referred to as axial movement, traverse, elongation or extension.

BELLOWS

The flexible element of an Expansion Joint consisting of one or more convolutions and the end tangents with $L_b / D_b \leq 3$, $nt \leq 0.375$ in. (9.53 mm), r_{ic} and $r_{ir} \geq 3t$, $|r_{ic} - r_{ir}| \leq 0.2r_m$, with no more than five plies.

CONTROL RODS

Devices, usually in the form of rods or bars, attached to the Expansion Joint assembly whose primary function is to distribute the movement between the two bellows of a universal Expansion Joint. Control rods are not designed to restrain bellows pressure thrust.

CONVOLUTION

The smallest flexible unit of a bellows. The total movement capacity of a bellows is proportional to the number of convolutions.

COVER

A device used to provide limited protection of the exterior surface of the bellows of an expansion joint from foreign objects or mechanical damage. A cover is sometimes referred to as a shroud.

DIRECTIONAL ANCHOR

A directional or sliding anchor is one which is designed to absorb loading in one direction while permitting motion in another. It may be either a main or intermediate anchor, depending upon the application involved. When designed for the purpose, a directional anchor may also function as a pipe alignment guide. In the design of a directional anchor, an effort should be made to minimize the friction between its moving or sliding parts, since this will reduce the loading on the piping and equipment and insure proper functioning of the anchor.