International Building Code. Portable containers subject to shifting or upset shall be secured. Nesting shall be an acceptable means of securing containers.

5503.5.3 Securing of vaporizers. Vaporizers, heat exchangers and similar equipment shall be anchored to a suitable foundation and its connecting piping shall be sufficiently flexible to provide for the effects of expansion and contraction due to temperature changes.

5503.5.4 Physical protection. Containers, piping, valves, pressure relief devices, regulating equipment and other appurtenances shall be protected against physical damage and tampering.

5503.6 Electrical wiring and equipment. Electrical wiring and equipment shall comply with NFPA 70 and Sections 5503.6.1 and 5503.6.2.

5503.6.1 Location. Containers and systems shall not be located where they could become part of an electrical circuit.

5503.6.2 Electrical grounding and bonding. Containers and systems shall not be used for electrical grounding. Where electrical grounding and bonding is required, the system shall comply with NFPA 70. The grounding system shall be protected against corrosion, including corrosion caused by stray electric currents.

5503.7 Service and repair. Service, repair, modification or removal of valves, pressure relief devices or other container appurtenances shall comply with Sections 5503.7.1 and 5503.7.2 and the *ASME Boiler and Pressure Vessel Code*, Section VIII or DOTn 49 CFR Parts 100–185.

5503.7.1 Containers. Containers that have been removed from service shall be handled in an *approved* manner.

5503.7.2 Systems. Service and repair of systems shall be performed by trained personnel.

5503.8 Unauthorized use. Containers shall not be used for any purpose other than to serve as a vessel for containing the product that it is designed to contain.

5503.9 Leaks, damage and corrosion. Leaking, damaged or corroded containers shall be removed from service. Leaking, damaged or corroded systems shall be replaced, repaired or removed in accordance with Section 5503.7.

5503.10 Lighting. Where required, lighting, including emergency lighting, shall be provided for fire appliances and operating facilities such as walkways, control valves and gates ancillary to stationary containers.

SECTION 5504 STORAGE

5504.1 General. Storage of containers shall comply with this section.

5504.2 Indoor storage. Indoor storage of containers shall be in accordance with Sections 5504.2.1 through 5504.2.2.3.

5504.2.1 Stationary containers. Stationary containers shall be installed in accordance with the provisions applicable to the type of fluid stored and this section.

5504.2.1.1 Containers. Stationary containers shall comply with Section 5503.1.

5504.2.1.2 Construction of indoor areas. *Cryogenic fluids* in stationary containers stored indoors shall be located in buildings, rooms or areas constructed in accordance with the *International Building Code*.

5504.2.1.3 Ventilation. Storage areas for stationary containers shall be ventilated in accordance with the *International Mechanical Code*.

5504.2.2 Portable containers. Indoor storage of portable containers shall comply with the provisions applicable to the type of fluid stored and Sections 5504.2.2.1 through 5504.2.2.3.

5504.2.2.1 Containers. Portable containers shall comply with Section 5503.1.

5504.2.2.2 Construction of indoor areas. *Cryogenic fluids* in portable containers stored indoors shall be stored in buildings, rooms or areas constructed in accordance with the *International Building Code*.

5504.2.2.3 Ventilation. Storage areas shall be ventilated in accordance with the *International Mechanical Code*.

5504.3 Outdoor storage. Outdoor storage of containers shall be in accordance with Sections 5504.3.1 through 5504.3.1.2.3.

5504.3.1 Separation from hazardous conditions. Cryogenic containers and systems in outdoor storage shall be separated from materials and conditions that pose exposure hazards to or from each other in accordance with Sections 5504.3.1.1 through 5504.3.1.1.5.

5504.3.1.1 Stationary containers. Stationary containers shall be separated from exposure hazards in accordance with the provisions applicable to the type of fluid contained and the minimum separation distances indicated in Table 5504.3.1.1.

TABLE 5504.3.1.1 SEPARATION OF STATIONARY CONTAINERS FROM EXPOSURE HAZARDS

| EXPOSURE | MINIMUM DISTANCE (feet) | | |
|--|----------------------------------|--|--|
| Air intakes | 10 | | |
| Building exits | 10 | | |
| Buildings, regardless of construction type | 1 | | |
| Combustible materials such as paper, leaves, weeds, dry grass or debris | 15 | | |
| Lot lines | 5 | | |
| Nonambulatory patient areas | 50 | | |
| Other hazardous materials | In accordance with Chapter 50 | | |
| Places of public assembly | 50 | | |
| Wall openings | 1 | | |

For SI: 1 foot = 304.8 mm.

5504.3.1.1.1 Point-of-fill connections. Remote transfer points and fill connection points shall not be positioned closer to exposures than the minimum distances required for stationary containers.

5504.3.1.1.2 Surfaces beneath containers. Containers shall be placed on surfaces that are compatible with the fluid in the container.

5504.3.1.1.3 Location. Containers of *cryogenic fluids* shall not be located within diked areas containing other hazardous materials.

5504.3.1.1.4 Areas subject to flooding. Stationary containers located in areas subject to flooding shall be securely anchored or elevated to prevent the containers from separating from foundations or supports.

5504.3.1.1.5 Drainage. The area surrounding stationary containers shall be provided with a means to prevent accidental discharge of fluids from endangering personnel, containers, equipment and adjacent structures or to enter enclosed spaces. The stationary container shall not be placed where spilled or discharged fluids will be retained around the container.

Exception: These provisions shall not apply where it is determined by the *fire code official* that the container does not constitute a hazard, after consideration of special features such as crushed rock utilized as a heat sink, topographical conditions, nature of occupancy, proximity to structures on the same or adjacent property, and the capacity and construction of containers and character of fluids to be stored.

5504.3.1.2 Outdoor storage of portable containers. Outdoor storage of portable containers shall comply with Section 5503 and Sections 5504.3.1.2.1 through 5504.3.1.2.3.

5504.3.1.2.1 Exposure hazard separation. Portable containers in outdoor storage shall be separated from exposure hazards in accordance with Table 5504.3.1.2.1.

| TABLE 5504.3.1.2.1 |
|-----------------------------------|
| SEPARATION OF PORTABLE CONTAINERS |
| FROM EXPOSURE HAZARDS |

| EXPOSURE | MINIMUM DISTANCE (feet) | | | | |
|--|----------------------------------|--|--|--|--|
| Air intakes | 10 | | | | |
| Building exits | 10 | | | | |
| Combustible materials such as paper, leaves, weeds, dry grass or debris | 15 | | | | |
| Lot lines | 5 | | | | |
| Other hazardous materials | In accordance with Chapter 50 | | | | |
| Wall openings | 1 | | | | |

For SI: 1 foot = 304.8 mm.

5504.3.1.2.2 Surfaces beneath containers. The surface of the area on which stationary containers are placed, including the surface of the area located below the point where connections are made for the purpose of filling such containers, shall be compatible with the fluid in the container.

5504.3.1.2.3 Drainage. The area surrounding portable containers shall be provided with a means to prevent accidental discharge of fluids from endangering adjacent containers, buildings, equipment or adjoining property.

Exception: These provisions shall not apply where it is determined by the *fire code official* that the container does not constitute a hazard.

SECTION 5505 USE AND HANDLING

5505.1 General. Use and handling of *cryogenic fluid* containers and systems shall comply with Sections 5505.1.1 through 5505.5.2.

5505.1.1 Cryogenic fluid systems. *Cryogenic fluid* systems shall be suitable for the use intended and designed by persons competent in such design. Equipment, machinery and processes shall be *listed* or *approved*.

5505.1.2 Piping systems. Piping, tubing, valves and joints and fittings conveying *cryogenic fluids* shall be installed in accordance with the material-specific provisions of Section 5501.1 and Sections 5505.1.2.1 through 5505.1.2.6.

5505.1.2.1 Design and construction. Piping systems shall be suitable for the use intended through the full range of pressure and temperature to which they will be subjected. Piping systems shall be designed and constructed to provide adequate allowance for expansion, contraction, vibration, settlement and fire exposure.

5505.1.2.2 Joints. Joints on container piping and tubing shall be threaded, welded, silver brazed or flanged.

5505.1.2.3 Valves and accessory equipment. Valves and accessory equipment shall be suitable for the intended use at the temperatures of the application and shall be designed and constructed to withstand the maximum pressure at the minimum temperature to which they will be subjected.

5505.1.2.3.1 Shutoff valves on container s. Shutoff valves shall be provided on all container connections except for pressure relief devices. Shutoff valves shall be provided with access thereto and located as close as practical to the container.

5505.1.2.3.2 Shutoff valves on piping. Shutoff valves shall be installed in piping containing *cryogenic fluids* where needed to limit the volume of liquid discharged in the event of piping or equipment failure. Pressure relief valves shall be installed

where liquid is capable of being trapped between shutoff valves in the piping system (see Section 5503.2).

5505.1.2.4 Physical protection and support. Piping systems shall be supported and protected from physical damage. Piping passing through walls shall be protected from mechanical damage.

5505.1.2.5 Corrosion protection. Above-ground piping that is subject to corrosion because of exposure to corrosive atmospheres, shall be constructed of materials to resist the corrosive environment or otherwise protected against corrosion. Below-ground piping shall be protected against corrosion.

5505.1.2.6 Testing. Piping systems shall be tested and proven free of leaks after installation as required by the standards to which they were designed and constructed. Test pressures shall be not less than 150 percent of the maximum allowable working pressure where hydraulic testing is conducted or 110 percent where testing is conducted pneumatically.

5505.2 Indoor use. Indoor use of *cryogenic fluids* shall comply with the material-specific provisions of Section 5501.1.

5505.3 Outdoor use. Outdoor use of *cryogenic fluids* shall comply with the material specific provisions of Sections 5501.1, 5505.3.1 and 5505.3.2.

5505.3.1 Separation. Distances from *lot lines*, buildings and exposure hazards shall comply with Section 5504.3 and the material-specific provisions of Section 5501.1.

5505.3.2 Emergency shutoff valves. Manual or automatic emergency shutoff valves shall be provided to shut off the *cryogenic fluid* supply in case of emergency. An emergency shutoff valve shall be located at the source of supply and at the point where the system enters the building.

5505.4 Filling and dispensing. Filling and dispensing of *cryogenic fluids* shall comply with Sections 5505.4.1 through 5505.4.3.

5505.4.1 Dispensing areas. Dispensing of *cryogenic fluids* with physical or *health hazards* shall be conducted in *approved* locations. Dispensing indoors shall be conducted in areas constructed in accordance with the *International Building Code*.

5505.4.1.1 Ventilation. Indoor areas where *cryogenic fluids* are dispensed shall be ventilated in accordance with the requirements of the *International Mechanical Code* in a manner that captures any vapor at the point of generation.

Exception: *Cryogenic fluids* that can be demonstrated not to create harmful vapors.

5505.4.1.2 Piping systems. Piping systems utilized for filling or dispensing of *cryogenic fluids* shall be designed and constructed in accordance with Section 5505.1.2.

5505.4.2 Vehicle loading and unloading areas. Loading or unloading areas shall be conducted in an *approved* manner in accordance with the standards referenced in Section 5501.1.

5505.4.3 Limit controls. Limit controls shall be provided to prevent overfilling of stationary containers during filling operations.

5505.5 Handling. Handling of cryogenic containers shall comply with Sections 5505.5.1 and 5505.5.2.

5505.5.1 Carts and trucks. Cryogenic containers shall be moved using an *approved* method. Where cryogenic containers are moved by hand cart, hand truck or other mobile device, such carts, trucks or devices shall be designed for the secure movement of the container.

Carts and trucks used to transport cryogenic containers shall be designed to provide a stable base for the commodities to be transported and shall have a means of restraining containers to prevent accidental dislodgement.

5505.5.2 Closed containers. Pressurized containers shall be transported in a closed condition. Containers designed for use at atmospheric conditions shall be transported with appropriate loose-fitting covers in place to prevent spillage.

CHAPTER 56 EXPLOSIVES AND FIREWORKS

User note:

About this chapter: Chapter 56 prescribes minimum requirements for the safe manufacture, storage, handling and use of explosives, ammunition and blasting agents for commercial and industrial occupancies. These provisions are intended to protect the general public, emergency responders and individuals who handle explosives. It also regulates the manufacturing, retail sale, display and wholesale distribution of fireworks; establishes the requirements for obtaining approval to manufacture, store, sell, discharge or conduct a public display; and references national standards for regulations governing manufacture, storage and public displays.

SECTION 5601 GENERAL

5601.1 Scope. The provisions of this chapter shall govern the possession, manufacture, storage, handling, sale and use of *explosives, explosive materials*, fireworks and small arms ammunition.

Exceptions:

- 1. The Armed Forces of the United States, Coast Guard or National Guard.
- 2. *Explosives* in forms prescribed by the official United States Pharmacopoeia.
- 3. The possession, storage and use of small arms ammunition where packaged in accordance with DOTn packaging requirements.
- 4. The possession, storage and use of not more than 1 pound (0.454 kg) of commercially manufactured sporting black powder, 20 pounds (9 kg) of smokeless powder and 10,000 small arms primers for hand loading of small arms ammunition for personal consumption.
- 5. The use of *explosive materials* by federal, state and local regulatory, law enforcement and fire agencies acting in their official capacities.
- 6. Special industrial *explosive* devices that in the aggregate contain less than 50 pounds (23 kg) of *explosive materials*.
- 7. The possession, storage and use of blank industrial-power load cartridges where packaged in accordance with DOTn packaging regulations.
- 8. Transportation in accordance with DOTn 49 CFR Parts 100–185.
- 9. Items preempted by federal regulations.

5601.1.1 Explosive material standard. In addition to the requirements of this chapter, NFPA 495 shall govern the manufacture, transportation, storage, sale, handling and use of *explosive materials*.

5601.1.2 Explosive material terminals. In addition to the requirements of this chapter, the operation of *explosive material* terminals shall conform to the provisions of NFPA 498.

5601.1.3 Fireworks. The possession, manufacture, storage, sale, handling and use of fireworks are prohibited.

Exceptions:

- 1. Storage and handling of fireworks as allowed in Section 5604.
- 2. Manufacture, assembly and testing of fireworks as allowed in Section 5605.
- 3. The use of fireworks for fireworks displays as allowed in Section 5608.
- 4. The possession, storage, sale, handling and use of specific types of Division 1.4G fireworks where allowed by applicable laws, ordinances and regulations, provided that such fireworks and facilities comply with the 2006 edition of NFPA 1124, CPSC 16 CFR Parts 1500 and 1507, and DOTn 49 CFR Parts 100–185, as applicable for consumer fireworks.

5601.1.4 Rocketry. The storage, handling and use of model and high-power rockets shall comply with the requirements of NFPA 1122, NFPA 1125 and NFPA 1127.

5601.1.5 Ammonium nitrate. The storage and handling of ammonium nitrate shall comply with the requirements of NFPA 400 and Chapter 63.

Exception: Storage of ammonium nitrate in magazines with blasting agents shall comply with the requirements of NFPA 495.

5601.2 Permit required. Permits shall be required as set forth in Section 105.5 and regulated in accordance with this section.

5601.2.1 Residential uses. Persons shall not keep or store, nor shall any permit be issued to keep or store, any *explosives* at any place of habitation, or within 100 feet (30 480 mm) thereof.

Exception: Storage of smokeless propellant, black powder and small arms primers for personal use and not for resale in accordance with Section 5606.

5601.2.2 Sale and retail display. Persons shall not construct a retail display nor offer for sale *explosives*, *explosive materials* or fireworks on highways, sidewalks, public property or in Group A or E occupancies.

5601.2.3 Permit restrictions. The *fire code official* is authorized to limit the quantity of *explosives*, *explosive materials* or fireworks permitted at a given location. Persons possessing a permit for storage of *explosives* at any place, shall not keep or store an amount greater than authorized in such permit. Only the kind of *explosive* specified in such a permit shall be kept or stored.

5601.2.4 Financial responsibility. Before a permit is issued, as required by Section 5601.2, the applicant shall file with the jurisdiction a corporate surety bond in the principal sum of \$100,000 or a public liability insurance policy for the same amount, for the purpose of the payment of all damages to persons or property that arise from, or are caused by, the conduct of any act authorized by the permit upon which any judicial judgment results. The *fire code official* is authorized to specify a greater or lesser amount when, in his or her opinion, conditions at the location of use indicate a greater or lesser amount is required. Government entities shall be exempt from this bond requirement.

5601.2.4.1 Blasting. Before approval to do blasting is issued, the applicant for approval shall file a bond or submit a certificate of insurance in such form, amount and coverage as determined by the legal department of the jurisdiction to be adequate in each case to indemnify the jurisdiction against any and all damages arising from permitted blasting.

5601.2.4.2 Fireworks display. The permit holder shall furnish a bond or certificate of insurance in an amount deemed adequate by the *fire code official* for the payment of all potential damages to a person or persons or to property by reason of the permitted display, and arising from any acts of the permit holder, the agent, employees or subcontractors.

5601.3 Prohibited explosives. Permits shall not be issued or renewed for possession, manufacture, storage, handling, sale or use of the following materials and such materials currently in storage or use shall be disposed of in an *approved* manner.

- 1. Liquid nitroglycerin.
- 2. Dynamite containing more than 60-percent liquid *explosive* ingredient.
- 3. Dynamite having an unsatisfactory absorbent or one that permits leakage of a liquid *explosive* ingredient under any conditions liable to exist during storage.
- 4. Nitrocellulose in a dry and uncompressed condition in a quantity greater than 10 pounds (4.54 kg) of net weight in one package.
- 5. Fulminate of mercury in a dry condition and fulminate of all other metals in any condition except as a component of manufactured articles not hereinafter forbidden.
- Explosive compositions that ignite spontaneously or undergo marked decomposition, rendering the products of their use more hazardous, when subjected for 48 consecutive hours or less to a temperature of 167°F (75°C).

- 7. New *explosive materials* until *approved* by DOTn, except that permits are allowed to be issued to educational, governmental or industrial laboratories for instructional or research purposes.
- 8. *Explosive materials* forbidden for transport by DOTn.
- 9. *Explosive materials* containing an ammonium salt and a chlorate.
- 10. *Explosives* not packed or marked as required by DOTn 49 CFR Parts 100–185.

Exception: Gelatin dynamite.

5601.4 Qualifications. Persons in charge of magazines, blasting, fireworks display or pyrotechnic special effect operations shall not be under the influence of alcohol or drugs that impair sensory or motor skills, shall be not less than 21 years of age and shall demonstrate knowledge of all safety precautions related to the storage, handling or use of *explosives, explosive materials* or fireworks.

5601.5 Supervision. The *fire code official* is authorized to require operations permitted under the provisions of Section 5601.2 to be supervised at any time by the *fire code official* in order to determine compliance with all safety and fire regulations.

5601.6 Notification. Whenever a new *explosive material* storage or manufacturing site is established, including a temporary job site, the local law enforcement agency, fire department and local emergency planning committee shall be notified 48 hours in advance, not including Saturdays, Sundays and holidays, of the type, quantity and location of *explosive materials* at the site.

5601.7 Seizure. The *fire code official* is authorized to remove or cause to be removed or disposed of in an *approved* manner, at the expense of the *owner*, *explosives*, *explosive materials* or fireworks offered or exposed for sale, stored, possessed or used in violation of this chapter.

5601.8 Establishment of quantity of explosives and distances. The quantity of *explosives* and distances shall be in accordance with Sections 5601.8.1 through 5601.8.1.4.

5601.8.1 Quantity of explosives. The quantity-distance (Q-D) tables in Sections 5604.5 and 5605.3 shall be used to provide the minimum separation distances from potential explosion sites as set forth in Tables 5601.8.1(1) through 5601.8.1(3). The classification and the weight of the *explosives* are primary characteristics governing the use of these tables. The net *explosive* weight shall be determined in accordance with Sections 5601.8.1.1 through 5601.8.1.4.

5601.8.1.1 Mass-detonating explosives (Division 1.1, 1.2 or 1.5). The total net *explosive* weight of mass-detonating *explosives* (Division 1.1, 1.2 or 1.5) shall be used. See Table 5604.5.2(1) or Table 5605.3, as appropriate.

Exception: Where the TNT equivalence of the *explosive material* has been determined, the equivalence is allowed to be used to establish the net *explosive* weight.

| ITEM | MAGAZINE | MAGAZINE OPERATING BUILDING | | PUBLIC TRAFFIC ROUTE | | | | | | |
|----------------------|--|---|--------------------------|--------------------------|--|--|--|--|--|--|
| Inhabited building | IBD in Table 5604.5.2(1) | 04.5.2(1) IBD in Table 5604.5.2(1) Not Applicable | | Not Applicable | | | | | | |
| Magazine | IMD in Table 5604.5.2(1) | ILD or IPD in Table 5605.3 | IBD in Table 5604.5.2(1) | PTR in Table 5604.5.2(1) | | | | | | |
| Operating building | ILD or IPD in Table 5604.5.2(1)ILD or IPD in Table 5605.3IBD | | IBD in Table 5604.5.2(1) | PTR in Table 5604.5.2(1) | | | | | | |
| Public traffic route | ic route PTR in Table 5604.5.2(1) PTR in Table 5604.5.2(1) Not | | Not Applicable | Not Applicable | | | | | | |

TABLE 5601.8.1(1) APPLICATION OF QUANTITY-DISTANCE (Q-D) TABLES—DIVISION 1.1, 1.2 AND 1.5 EXPLOSIVES^{a, b, c}

For SI: 1 foot = 304.8 mm.

a. The minimum separation distance shall be 60 feet. Where a building or magazine containing explosives is barricaded, the minimum distance shall be 30 feet.

b. Linear interpolation between tabular values in the referenced Q-D tables shall not be allowed. Nonlinear interpolation of the values shall be allowed subject to an approved technical opinion and report prepared in accordance with Section 104.8.2.

c. For definitions of quantity-distance abbreviations IBD, ILD, IMD, IPD and PTR, see Chapter 2.

| TABLE 5601.8.1(2) | |
|--|--|
| APPLICATION OF QUANTITY-DISTANCE (Q-D) TABLES—DIVISION 1.3 EXPLOSIVES ^{a, b, c} | |

| ITEM MAGAZINE | | OPERATING BUILDING | INHABITED BUILDING | PUBLIC TRAFFIC ROUTE | |
|----------------------|--|------------------------------------|--------------------------|--------------------------|--|
| Inhabited building | Iding IBD in Table 5604.5.2(2) IBD in Table 5604.5.2(2) Not Applicable | | Not Applicable | | |
| Magazine | IMD in Table 5604.5.2(2) | ILD or IPD in Table 5604.5.2(2) | IBD in Table 5604.5.2(2) | PTR in Table 5604.5.2(2) | |
| Operating building | ng building ILD or IPD in ILD or IPD in Table 5604.5.2(2) Table 5604.5.2(2) | | IBD in Table 5604.5.2(2) | PTR in Table 5604.5.2(2) | |
| Public traffic route | PTR in Table 5604.5.2(2) | PTR in Table 5604.5.2(2) | Not Applicable | Not Applicable | |

For SI: 1 foot = 304.8 mm.

a. The minimum separation distance hall be not less than 50 feet.

b. Linear interpolation between tabular values in the referenced Q-D table shall be allowed.

c. For definitions of quantity-distance abbreviations IBD, ILD, IMD, IPD and PTR, see Chapter 2.

| TABLE 5601.8.1(3) | |
|--|--|
| APPLICATION OF QUANTITY-DISTANCE (Q-D) TABLES—DIVISION 1.4 EXPLOSIVES ^{a, b, c} | |

| ITEM | MAGAZINE | OPERATING BUILDING | INHABITED BUILDING | PUBLIC TRAFFIC ROUTE | |
|----------------------|---|------------------------------------|--------------------------|--------------------------|--|
| Inhabited building | IBD in Table 5604.5.2(3) IBD in Table 5604.5.2(3) I | | Not Applicable | Not Applicable | |
| Magazine | IMD in Table 5604.5.2(3) | ILD or IPD in Table 5604.5.2(3) | IBD in Table 5604.5.2(3) | PTR in Table 5604.5.2(3) | |
| Operating building | ILD or IPD in Table 5604.5.2(3) | ILD or IPD in Table 5604.5.2(3) | IBD in Table 5604.5.2(3) | PTR in Table 5604.5.2(3) | |
| Public traffic route | PTR in Table 5604.5.2(3) | PTR in Table 5604.5.2(3) | Not Applicable | Not Applicable | |

For SI: 1 foot = 304.8 mm.

a. The minimum separation distance shall be not less than 50 feet.

b. Linear interpolation between tabular values in the referenced Q-D table shall not be allowed.

c. For definitions of quantity-distance abbreviations IBD, ILD, IMD, IPD and PTR, see Chapter 2.

5601.8.1.2 Nonmass-detonating explosives (excluding Division 1.4). Nonmass-detonating *explosives* (excluding Division 1.4) shall be as follows:

- 1. Division 1.3 propellants. The total weight of the propellants alone shall be the net *explosive* weight. The net weight of propellant shall be used. See Table 5604.5.2(2).
- 2. Combinations of bulk metal powder and pyrotechnic compositions. The sum of the net weights of metal powders and pyrotechnic compositions in the containers shall be the net *explosive* weight. See Table 5604.5.2(2).

5601.8.1.3 Combinations of mass-detonating and nonmass-detonating explosives (excluding Division 1.4). Combination of mass-detonating and nonmass-detonating *explosives* (excluding Division 1.4) shall be as follows:

1. Where Division 1.1 and 1.2 *explosives* are located in the same site, determine the distance for the total quantity considered first as 1.1 and then as 1.2. The required distance is the greater of the two. Where the Division 1.1 requirements are controlling and the TNT equivalence of the 1.2 is known, the TNT equivalent weight of the 1.2 items shall be allowed to be added to

the total *explosive* weight of Division 1.1 items to determine the net *explosive* weight for Division 1.1 distance determination. See Table 5604.5.2(2) or Table 5605.3, as appropriate.

- 2. Where Division 1.1 and 1.3 *explosives* are located in the same site, determine the distances for the total quantity considered first as 1.1 and then as 1.3. The required distance is the greater of the two. Where the Division 1.1 requirements are controlling and the TNT equivalence of the 1.3 is known, the TNT equivalent weight of the 1.3 items shall be allowed to be added to the total *explosive* weight of Division 1.1 items to determine the net *explosive* weight for Division 1.1 distance determination. See Table 5604.5.2(1), 5604.5.2(2) or 5605.3, as appropriate.
- 3. Where Division 1.1, 1.2 and 1.3 *explosives* are located in the same site, determine the distances for the total quantity considered first as 1.1, next as 1.2 and finally as 1.3. The required distance is the greatest of the three. As allowed by Items 1 and 2, TNT equivalent weights for 1.2 and 1.3 items are allowed to be used to determine the net weight of *explosives* for Division 1.1 distance determination. Table 5604.5.2(1) or Table 5605.3 shall be used where TNT equivalency is used to establish the net *explosive* weight.
- 4. For composite pyrotechnic items Division 1.1 and Division 1.3, the sum of the net weights of the pyrotechnic composition and the *explosives* involved shall be used. See Tables 5604.5.2(1) and 5604.5.2(2).

5601.8.1.4 Moderate fire—no blast hazards (Division 1.4). For Division 1.4 *explosives*, the total weight of the *explosive material* alone is the net weight. The net weight of the *explosive material* shall be used.

SECTION 5602 DEFINITIONS

5602.1 Definitions. The following terms are defined in Chapter 2:

AMMONIUM NITRATE.

BARRICADE.

Artificial barricade. Natural barricade.

BARRICADED.

BLAST AREA.

BLAST SITE.

BLASTER.

BLASTING AGENT.

BULLET RESISTANT. DETONATING CORD.

DETONATION. DETONATOR. DISCHARGE SITE. DISPLAY SITE. EXPLOSIVE. High explosive. Low explosive. Mass-detonating explosives. UN/DOTn Class 1 explosives. Division 1.1. Division 1.2. Division 1.3. Division 1.4. Division 1.5. Division 1.6. EXPLOSIVE MATERIAL. FALLOUT AREA. FIREWORKS. Fireworks, 1.3G. Fireworks, 1.4G. FIREWORKS DISPLAY. HIGHWAY. INHABITED BUILDING. MAGAZINE. Indoor. Type 1. Type 2. Type 3. Type 4. Type 5. MORTAR. NET EXPLOSIVE WEIGHT (net weight). OPERATING BUILDING. OPERATING LINE. PLOSOPHORIC MATERIAL. PROXIMATE AUDIENCE. PUBLIC TRAFFIC ROUTE (PTR). PYROTECHNIC ARTICLE. PYROTECHNIC COMPOSITION. PYROTECHNIC SPECIAL EFFECT. PYROTECHNIC SPECIAL-EFFECT MATERIAL. PYROTECHNICS. QUANTITY-DISTANCE (Q-D).

Inhabited building distance (IBD). Intermagazine distance (IMD).

Intraline distance (ILD) or Intraplant distance (IPD).

RAILWAY. READY BOX. SMALL ARMS AMMUNITION. SMALL ARMS PRIMERS. SMOKELESS PROPELLANTS. SPECIAL INDUSTRIAL EXPLOSIVE DEVICE. THEFT RESISTANT.

SECTION 5603 RECORD KEEPING AND REPORTING

5603.1 General. Records of the receipt, handling, use or disposal of *explosive materials*, and reports of any accidents, thefts or unauthorized activities involving *explosive materials* shall conform to the requirements of this section.

5603.2 Transaction record. The permittee shall maintain a record of all transactions involving receipt, removal, use or disposal of *explosive materials*. Such records shall be maintained for a period of 5 years.

Exception: Where only Division 1.4G (consumer fire-works) are handled, records need only be maintained for a period of 3 years.

5603.3 Loss, theft or unauthorized removal. The loss, theft or unauthorized removal of *explosive materials* from a magazine or permitted facility shall be reported to the *fire code official*, local law enforcement authorities and the US Department of Treasury, Bureau of Alcohol, Tobacco, Firearms and Explosives within 24 hours.

Exception: Loss of Division 1.4G (consumer fireworks) need not be reported to the Bureau of Alcohol, Tobacco, Firearms and Explosives.

5603.4 Accidents. Accidents involving the use of *explosives*, *explosive materials* and fireworks that result in injuries or property damage shall be reported to the *fire code official* immediately.

5603.5 Misfires. The pyrotechnic display operator or blaster in charge shall keep a record of all aerial shells that fail to fire or charges that fail to detonate.

5603.6 Hazard communication. Manufacturers of *explosive materials* and fireworks shall maintain records of chemicals, chemical compounds and mixtures required by DOL 29 CFR Part 1910.1200 and Section 407.

5603.7 Safety rules. Current safety rules covering the operation of magazines, as described in Section 5604.7, shall be posted on the interior of the magazine in a visible location.

SECTION 5604 EXPLOSIVE MATERIALS STORAGE AND HANDLING

5604.1 General. Storage of *explosives* and *explosive materials*, small arms ammunition, small arms primers, propellant-actuated cartridges and smokeless propellants in magazines shall comply with the provisions of this section.

5604.2 Magazine required. *Explosives* and *explosive materials*, and Division 1.3G fireworks shall be stored in magazines constructed, located, operated and maintained in accordance with the provisions of Section 5604 and NFPA 495 or NFPA 1124.

Exceptions:

- Storage of fireworks at display sites in accordance with Section 5608.5 and NFPA 1123 or NFPA 1126.
- 2. Portable or mobile magazines not exceeding 120 square feet (11 m²) in area shall not be required to comply with the requirements of the *International Building Code*.

5604.3 Magazines. The storage of *explosives* and *explosive materials* in magazines shall comply with Table 5604.3.

5604.3.1 High explosives. *Explosive materials* classified as Division 1.1 or 1.2 or formerly classified as Class A by the US Department of Transportation shall be stored in Type 1, 2 or 3 magazines.

Exceptions:

- 1. Black powder shall be stored in a Type 1, 2, 3 or 4 magazine.
- 2. Cap-sensitive *explosive material* that is demonstrated not to be bullet sensitive shall be stored in a Type 1, 2, 3, 4 or 5 magazine.

5604.3.2 Low explosives. *Explosive materials* that are not cap sensitive shall be stored in a Type 1, 2, 3, 4 or 5 magazine.

5604.3.3 Detonating cord. For quantity and distance purposes, detonating cord of 50 grains per foot shall be calculated as equivalent to 8 pounds (4 kg) of high *explosives* per 1,000 feet (305 m). Heavier or lighter core loads shall be rated proportionally.

5604.4 Prohibited storage. Detonators shall be stored in a separate magazine for blasting supplies and shall not be stored in a magazine with other *explosive materials*.

5604.5 Location. The use of magazines for storage of *explosives* and *explosive materials* shall comply with Sections 5604.5.1 through 5604.5.3.3.

5604.5.1 Indoor magazines. The use of indoor magazines for storage of *explosives* and *explosive materials* shall comply with the requirements of Sections 5604.5.1.1 through 5604.5.1.7.

5604.5.1.1 Use. The use of indoor magazines for storage of *explosives* and *explosive materials* shall be limited to occupancies of Group F, H, M or S, and research and development laboratories.

5604.5.1.2 Construction. Indoor magazines shall comply with the following construction requirements:

- 1. Construction shall be fire resistant and theft resistant.
- 2. Exterior shall be painted red.

| NEW | | INDOOR ^a (pounds) | | | | | MAGAZINE TYPE REQUIRED | | | | | |
|---------------------|----------------|------------------------------|---------|------------|-------------------------|----------|------------------------|---|---|---|---|---|
| UN/DOTn DIVISION | CLASS | Unprotected | Cabinet | Sprinklers | Sprinklers & cabinet | (pounds) | 1 | 2 | 3 | 4 | 5 | |
| 1.1 ^b | А | High | 0 | 0 | 1 | 2 | 1 | Х | Х | Х | | |
| 1.2 | А | High | 0 | 0 | 1 | 2 | 1 | Х | Х | Х | | |
| 1.2 | В | Low | 0 | 0 | 1 | 1 | 1 | Х | Х | Х | Х | |
| 1.3 | В | Low | 0 | 0 | 5 | 10 | 1 | Х | Х | Х | Х | _ |
| 1.4 | В | Low | 0 | 0 | 50 | 100 | 1 | Х | Х | Х | Х | |
| 1.5 | С | Low | 0 | 0 | 1 | 2 | 1 | Х | Х | Х | Х | |
| 1.5 | Blasting Agent | Blasting Agent | 0 | 0 | 1 | 2 | 1 | Х | Х | Х | Х | Х |
| 1.6 | Not Applicable | Not Applicable | 0 | 0 | 1 | 2 | 1 | Х | Х | Х | Х | Х |

TABLE 5604.3 STORAGE AMOUNTS AND MAGAZINE REQUIREMENTS FOR EXPLOSIVES, EXPLOSIVE MATERIALS AND FIREWORKS, 1.3G MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA

For SI: 1 pound = 0.454 kg, 1 pound per gallon = 0.12 kg per liter, 1 ounce = 28.35 g.

a. A factor of 10 pounds per gallon shall be used for converting pounds (solid) to gallons (liquid) in accordance with Section 5003.1.2.

b. Black powder shall be stored in a Type 1, 2, 3 or 4 magazine as provided for in Section 5604.3.1.

- 3. Base shall be fitted with wheels, casters or rollers to facilitate removal from the building in an emergency.
- 4. Lid or door shall be marked with conspicuous white lettering not less than 3 inches (76 mm) high and minimum ¹/₂ inch (12.7 mm) stroke, reading "EXPLOSIVES—KEEP FIRE AWAY."
- 5. The least horizontal dimension shall not exceed the clear width of the entrance door.

5604.5.1.3 Quantity limit. Not more than 50 pounds (23 kg) of *explosives* or *explosive materials* shall be stored within an indoor magazine.

Exception: Day boxes used for the storage of inprocess material in accordance with Section 5605.6.4.1.

5604.5.1.4 Prohibited use. Indoor magazines shall not be used within buildings containing Group R occupancies.

5604.5.1.5 Location. Indoor magazines shall be located within 10 feet (3048 mm) of an entrance and only on floors at or having *ramp* access to the exterior grade level.

5604.5.1.6 Number. Not more than two indoor magazines shall be located in the same building. Where two such magazines are located in the same building, one magazine shall be used solely for the storage of not more than 5,000 detonators.

5604.5.1.7 Separation distance. Where two magazines are located in the same building, they shall be separated by a distance of not less than 10 feet (3048 mm).

5604.5.2 Outdoor magazines. Outdoor magazines other than Type 3 shall be located so as to comply with Table 5604.5.2(2) or 5604.5.2(3) as set forth in Tables 5601.8.1(1) through 5601.8.1(3). Where a magazine or

group of magazines, as described in Section 5604.5.2.2, contains different classes of *explosive materials*, and Division 1.1 materials are present, the required separations for the magazine or magazine group as a whole shall comply with Table 5604.5.2(2).

5604.5.2.1 Separation. Where two or more storage magazines are located on the same property, each magazine shall comply with the minimum distances specified from inhabited buildings, public transportation routes and operating buildings. Magazines shall be separated from each other by not less than the intermagazine distances (IMD) shown for the separation of magazines.

5604.5.2.2 Grouped magazines. Where two or more magazines are separated from each other by less than the intermagazine distances (IMD), such magazines as a group shall be considered as one magazine and the total quantity of *explosive materials* stored in the group shall be treated as if stored in a single magazine. The location of the group of magazines shall comply with the intermagazine distances (IMD) specified from other magazines or magazine groups, inhabited buildings (IBD), public transportation routes (PTR) and operating buildings (ILD or IPD) as required.

5604.5.3 Special requirements for Type 3 magazines. Type 3 magazines shall comply with Sections 5604.5.3.1 through 5604.5.3.3.

5604.5.3.1 Location. Wherever practicable, Type 3 magazines shall be located away from neighboring inhabited buildings, railways, highways and other magazines in accordance with Table 5604.5.2(2) or 5604.5.2(3), as applicable.

5604.5.3.2 Supervision. Type 3 magazines shall be attended when *explosive materials* are stored within. *Explosive materials* shall be removed to appropriate storage magazines for unattended storage at the end of the workday.

TABLE 5604.5.2(1) AMERICAN TABLE OF DISTANCES FOR STORAGE OF EXPLOSIVES AS APPROVED BY THE INSTITUTE OF MAKERS OF EXPLOSIVES AND REVISED JUNE 1991^a

| | | DISTANCES IN FEET | | | | | | | | |
|-------------|-----------------------|-------------------|--------------|---|---|--|---|--------------------------------------|--------------|--|
| QUANTITY O | F EXPLOSIVE RIALS° | Inhabited | buildings | Public highwa volume les vehicles | ays with traffic s than 3,000 s per day | Public highwa volume grea vehicles p passenge | ays with traffic ter than 3,000 er day and er railways | Separation of magazines ^d | | |
| Pounds over | Pounds not over | Barricaded | Unbarricaded | Barricaded | Unbarricaded | Barricaded | arricaded Unbarricaded | | Unbarricaded | |
| 0 | 5 | 70 | 140 | 30 | 60 | 51 | 102 | 6 | 12 | |
| 5 | 10 | 90 | 180 | 35 | 70 | 64 | 128 | 8 | 16 | |
| 10 | 20 | 110 | 220 | 45 | 90 | 81 | 162 | 10 | 20 | |
| 20 | 30 | 125 | 250 | 50 | 100 | 93 | 186 | 11 | 22 | |
| 30 | 40 | 140 | 280 | 55 | 110 | 103 | 206 | 12 | 24 | |
| 40 | 50 | 150 | 300 | 60 | 120 | 110 | 220 | 14 | 28 | |
| 50 | 75 | 170 | 340 | 70 | 140 | 127 | 254 | 15 | 30 | |
| 75 | 100 | 190 | 380 | 75 | 150 | 139 | 278 | 16 | 32 | |
| 100 | 125 | 200 | 400 | 80 | 160 | 150 | 300 | 18 | 36 | |
| 125 | 150 | 215 | 430 | 85 | 170 | 159 | 318 | 19 | 38 | |
| 150 | 200 | 235 | 470 | 95 | 190 | 175 | 350 | 21 | 42 | |
| 200 | 250 | 255 | 510 | 105 | 210 | 189 | 378 | 23 | 46 | |
| 250 | 300 | 270 | 540 | 110 | 220 | 201 | 402 | 24 | 48 | |
| 300 | 400 | 295 | 590 | 120 | 240 | 221 | 442 | 27 | 54 | |
| 400 | 500 | 320 | 640 | 130 | 260 | 238 | 476 | 29 | 58 | |
| 500 | 600 | 340 | 680 | 135 | 270 | 253 | 506 | 31 | 62 | |
| 600 | 700 | 355 | 710 | 145 | 290 | 266 | 532 | 32 | 64 | |
| 700 | 800 | 375 | 750 | 150 | 300 | 278 | 556 | 33 | 66 | |
| 800 | 900 | 390 | 780 | 155 | 310 | 289 | 578 | 35 | 70 | |
| 900 | 1,000 | 400 | 800 | 160 | 320 | 300 | 600 | 36 | 72 | |
| 1,000 | 1,200 | 425 | 850 | 165 | 330 | 318 | 636 | 39 | 78 | |
| 1,200 | 1,400 | 450 | 900 | 170 | 340 | 336 | 672 | 41 | 82 | |
| 1,400 | 1,600 | 470 | 940 | 175 | 350 | 351 | 702 | 43 | 86 | |
| 1,600 | 1,800 | 490 | 980 | 180 | 360 | 366 | 732 | 44 | 88 | |
| 1,800 | 2,000 | 505 | 1,010 | 185 | 370 | 378 | 756 | 45 | 90 | |
| 2,000 | 2,500 | 545 | 1,090 | 190 | 380 | 408 | 816 | 49 | 98 | |
| 2,500 | 3,000 | 580 | 1,160 | 195 | 390 | 432 | 864 | 52 | 104 | |
| 3,000 | 4,000 | 635 | 1,270 | 210 | 420 | 474 | 948 | 58 | 116 | |
| 4,000 | 5,000 | 685 | 1,370 | 225 | 450 | 513 | 1,026 | 61 | 122 | |
| 5,000 | 6,000 | 730 | 1,460 | 235 | 470 | 546 | 1,092 | 65 | 130 | |
| 6,000 | 7,000 | 770 | 1,540 | 245 | 490 | 573 | 1,146 | 68 | 136 | |
| 7,000 | 8,000 | 800 | 1,600 | 250 | 500 | 600 | 1,200 | 72 | 144 | |
| 8,000 | 9,000 | 835 | 1,670 | 255 | 510 | 624 | 1,248 | 75 | 150 | |
| 9,000 | 10,000 | 865 | 1,730 | 260 | 520 | 645 | 1,290 | 78 | 156 | |
| 10,000 | 12,000 | 875 | 1,750 | 270 | 540 | 687 | 1,374 | 82 | 164 | |
| 12,000 | 14,000 | 885 | 1,770 | 275 | 550 | 723 | 1,446 | 87 | 174 | |
| 14,000 | 16,000 | 900 | 1,800 | 280 | 560 | 756 | 1,512 | 90 | 180 | |
| 16,000 | 18,000 | 940 | 1,880 | 285 | 570 | 786 | 1,572 | 94 | 188 | |

(continued)