



**STANDARD FOR
NEUTRAL-SUPPORTED POWER CABLE ASSEMBLIES
WITH WEATHER-RESISTANT EXTRUDED INSULATION
RATED 600 VOLTS**

**Approved by
AMERICAN NATIONAL STANDARDS INSTITUTE**

July 15, 2011

Publication # ANSI/ICEA S-76-474-2011

**©2011 by
INSULATED CABLE ENGINEERS ASSOCIATION, Inc.**

Approved as an American National Standard
ANSI Approval Date: July 15, 2011

ANSI/ICEA Publication S-76-474 - 2011

*Standard For Neutral-Supported Power Cable Assemblies With
Weather-Resistant Extruded Insulation
Rated 600 Volts*

Developed and Published By

Insulated Cable Engineer's Association, Inc.
Post Office Box 1568
Carrollton, Georgia, 30112, USA

© Copyright 2011 by the Insulated Cable Engineers Association, Incorporated. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

[This is a preview. Click here to purchase the full publication.](#)

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While ICEA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgements contained in its standards and guideline publications.

ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. ICEA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, ICEA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgement or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

ICEA has no power, nor does it undertake to police or enforce compliance with the contents of this document. ICEA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to ICEA and is solely the responsibility of the certifier or maker of the statement.

Contents

	Page
Foreword	iv
Section 1	General
1.1	Scope.....
1.2	Assemblies.....
1.3	Design Options.....
1.4	Operating Conditions.....
1.5	Testing and Test Frequency.....
1.6	Test Methods.....
Section 2	COMPONENT CHARACTERISTICS AND REQUIREMENTS
2.0	General.....
2.1	Physical and Electrical Properties.....
2.1.1	Aluminum.....
2.1.2	Copper.....
2.2	Phase Conductors.....
2.2.1	Aluminum Phase Conductors.....
2.2.2	Copper Phase Conductors.....
2.3	Neutral Conductors.....
2.3.1	Aluminum Alloy 6201-T81.....
2.3.2	Aluminum 1350.....
2.3.3	Aluminum Conductor, Coated-Steel Reinforced (ACSR).....
2.3.4	Aluminum Conductor, Aluminum-Clad Steel Reinforced (ACSR/AW).....
2.3.5	Hard Drawn Copper.....
2.3.6	Copper and Copper-Clad Steel Composite.....
2.3.7	Coated Steel Wires.....
2.4	Conductor Size Units.....
2.5	Bare Neutral Conductor Size Determination.....
2.6	Conductor Diameter.....
2.7	Binders.....
2.7.1	Options.....
Section 3	INSULATION
3.1	Insulation or Covering.....
3.1.1	75°C Normal Service Operation Insulation.....
3.1.2	90°C Normal Service Operation Insulation.....
3.1.3	Alternate Insulation.....
3.2	Neutral Coverings.....
3.3	Binder Coverings.....
3.3.1	Covering.....
3.3.2	Covering Thickness.....
3.4	Separator.....
3.5	Electrical Requirements.....
3.5.1	Voltage Tests.....
3.6	Insulation or Neutral Covering Requirements.....
3.6.1	Thickness Requirements.....
3.6.2	Physical Requirements.....