

TECHNICAL REPORT

IEC
TR 60071-4

First edition
2004-06

Insulation co-ordination –

**Part 4:
Computational guide to insulation co-ordination
and modelling of electrical networks**



Reference number
IEC/TR 60071-4:2004(E)

This is a preview. [Click here to purchase the full publication.](#)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site (www.iec.ch)**
- **Catalogue of IEC publications**
The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.
- **IEC Just Published**
This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.
- **Customer Service Centre**
If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL REPORT

IEC TR 60071-4

First edition
2004-06

Insulation co-ordination –

Part 4: Computational guide to insulation co-ordination and modelling of electrical networks

© IEC 2004 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XE**

For price, see current catalogue

This is a preview. [Click here to purchase the full publication.](#)

CONTENTS

FOREWORD.....	7
1 Scope and object.....	9
2 Normative references.....	9
3 Terms and definitions	9
4 List of symbols and acronyms	12
5 Types of overvoltages.....	12
6 Types of studies	13
6.1 Temporary overvoltages (TOV).....	14
6.2 Slow-front overvoltages (SFO).....	14
6.3 Fast-front overvoltages (FFO).....	15
6.4 Very-fast-front overvoltages (VFFO).....	15
7 Representation of network components and numerical considerations	15
7.1 General	15
7.2 Numerical considerations.....	15
7.3 Representation of overhead lines and underground cables	18
7.4 Representation of network components when computing temporary overvoltages	19
7.5 Representation of network components when computing slow-front overvoltages.....	25
7.6 Representation of network components when computing fast-front transients.....	30
7.7 Representation of network components when computing very-fast-front overvoltages.....	42
8 Temporary overvoltages analysis	44
8.1 General	44
8.2 Fast estimate of temporary overvoltages.....	45
8.3 Detailed calculation of temporary overvoltages [2], [9].....	45
9 Slow-front overvoltages analysis	48
9.1 General	48
9.2 Fast methodology to conduct SFO studies	48
9.3 Method to be employed.....	49
9.4 Guideline to conduct detailed statistical methods	49
10 Fast-front overvoltages analysis.....	52
10.1 General	52
10.2 Guideline to apply statistical and semi-statistical methods.....	53
11 Very-fast-front overvoltage analysis	58
11.1 General	58
11.2 Goal of the studies to be performed	58
11.3 Origin and typology of VFFO	58
11.4 Guideline to perform studies	60
12 Test cases.....	60
12.1 General	60
12.2 Case 1: TOV on a large transmission system including long lines.....	60
12.3 Case 2 (SFO) – Energization of a 500 kV line	68
12.4 Case 3 (FFO) – Lightning protection of a 500 kV GIS substation	73
12.5 Case 4 (VFFO) – Simulation of transients in a 765 kV GIS [51]	80

Annex A (informative) Representation of overhead lines and underground cables	86
Annex B (informative) Arc modelling: the physics of the circuit-breaker	90
Annex C (informative) Probabilistic methods for computing lightning-related risk of failure of power system apparatus	93
Annex D (informative) Test case 5 (TOV) – Resonance between a line and a reactor in a 400/220 kV transmission system	99
Annex E (informative) Test case 6 (SFO) – Evaluation of the risk of failure of a gas-insulated line due to SFO	105
Annex F (informative) Test case 7 (FFO) – High-frequency arc extinction when switching a reactor	113
Bibliography	116
Figure 1 – Types of overvoltages (excepted very-fast-front overvoltages).....	12
Figure 2 – Damping resistor applied to an inductance	17
Figure 3 – Damping resistor applied to a capacitance	17
Figure 4 – Example of assumption for the steady-state calculation of a non-linear element.....	17
Figure 5 – AC-voltage equivalent circuit.....	19
Figure 6 – Dynamic source modelling	20
Figure 7 – Linear network equivalent	21
Figure 8 – Representation of load in [56]	24
Figure 9 – Representation of the synchronous machine	26
Figure 10 – Diagram showing double distribution used for statistical switches	29
Figure 11 – Multi-story transmission tower [16], $H = l_1 + l_2 + l_3 + l_4$	31
Figure 12 – Example of a corona branch model	33
Figure 13 – Example of volt-time curve.....	34
Figure 14 – Double ramp shape.....	38
Figure 15 – CIGRE concave shape	39
Figure 16 – Simplified model of earthing electrode.....	41
Figure 17 – Example of a one-substation-deep network modelling	51
Figure 18 – Example of a two-substation-deep network modelling.....	51
Figure 19 – Application of statistical or semi-statistical methods	53
Figure 20 – Application of the electro-geometric model.....	56
Figure 21 – Limit function for the two random variables considered: the maximum value of the lightning current and the disruptive voltage	57
Figure 22 – At the GIS-air interface: coupling between enclosure and earth (Z_3), between overhead line and earth (Z_2) and between bus conductor and enclosure (Z_1) [33]	59
Figure 23 – Single-line diagram of the test-case system	62
Figure 24 – TOV at CHM7, LVD7 and CHE7 from system transient stability simulation.....	63
Figure 25 – Generator frequencies at generating centres Nos. 1, 2 and 3 from system transient stability simulation	64
Figure 26 – Block diagram of dynamic source model [55].....	65
Figure 27 – TOV at LVD7 – Electromagnetic transient simulation with 588 kV and 612 kV permanent surge arresters.....	66

Figure 28 – TOV at CHM7 – Electromagnetic transient simulation with 588 kV and 612 kV permanent surge arresters.....	67
Figure 29 – TOV at LVD7 – Electromagnetic transient simulation with 484 kV switched metal-oxide surge arresters.....	67
Figure 30 – TOV at CHM7 – Electromagnetic transient simulation with 484 kV switched metal-oxide surge arresters.....	67
Figure 31 – Representation of the system.....	68
Figure 32 – Auxiliary contact and main.....	70
Figure 33 – An example of cumulative probability function of phase-to-earth overvoltages and of discharge probability of insulation in a configuration with trapped charges and insertion resistors.....	72
Figure 34 – Number of failure for 1 000 operations versus the withstand voltage of the insulation.....	72
Figure 35 – Schematic diagram of a 500 kV GIS substation intended for lightning studies.....	74
Figure 36 – Waveshape of the lightning stroke current.....	75
Figure 37 – Response surface approximation (failure and safe-state representation for one GIS section (node)).....	77
Figure 38 – Limit-state representation in the probability space of the physical variables Risk evaluation.....	79
Figure 39 – Single-line diagram of a 765 kV GIS with a closing disconnecter.....	81
Figure 40 – Simulation scheme of the 765 kV GIS part involved in the transient phenomena of interest.....	81
Figure 41 – 4 ns ramp.....	84
Figure 42 – Switch operation.....	85
Figure A.1 – Pi-model.....	86
Figure A.2 – Representation of the single conductor line.....	87
Figure B.1 – SF ₆ circuit-breaker switching.....	91
Figure C.1 – Example of a failure domain.....	96
Figure D.1 – The line and the reactance are energized at the same time.....	99
Figure D.2 – Energization configuration of the line minimizing the risk of temporary overvoltage.....	100
Figure D.3 – Malfunction of a circuit-breaker pole during energization of a transformer.....	102
Figure D.4 – Voltage in substation B phase A whose pole has not closed.....	103
Figure D.5 – Voltage in substation B phase B whose pole closed correctly.....	103
Figure D.6 – Voltage in substation B phase A where the breaker failed to close (configuration of Figure D.2).....	104
Figure E.1 – Electric circuit used to perform closing overvoltage calculations.....	105
Figure E.2 – Calculated overvoltage distribution – Two estimated Gauss probability functions resulting from two different fitting criteria (the $U_{2\%}$ and $U_{10\%}$ guarantees a good fitting of the most dangerous overvoltages).....	107
Figure E.3 – Example of switching overvoltage between phases A and B and phase-to-earth (A and B).....	109
Figure E.4 – Voltage distribution along the GIL (ER-energization ED-energization under single-phase fault ChPg-trapped charges).....	110
Figure F.1 – Test circuit (Copyright1998 IEEE [48]).....	113
Figure F.2 – Terminal voltage and current of GCB model (Copyright 1998 IEEE [48]).....	113
Figure F.3 – Measured arc parameter (Copyright 1998 IEEE [48]).....	114

Figure F.4 – Circuit used for simulation	114
Figure F.5 – Comparison between measured and calculated results (Copyright 1998 IEEE [48])	115
Table 1 – Classes and shapes of overvoltages – Standard voltage shapes and standard withstand tests	13
Table 2 – Correspondence between events and most critical types of overvoltages generated	14
Table 3 – Application and limitation of current overhead line and underground cable models	18
Table 4 – Values of U_0 , k , DE for different configurations proposed by [59]	35
Table 5 – Minimum transformer capacitance to earth taken from [44]	37
Table 6 – Typical transformer capacitance to earth taken from [28]	37
Table 7 – Circuit-breaker capacitance to earth taken from [28]	37
Table 8 – Representation of the first negative downward strokes	40
Table 9 – Time to half-value of the first negative downward strokes	40
Table 10 – Representation of the negative downward subsequent strokes	40
Table 11 – Time to half-value of negative downward subsequent strokes	40
Table 12 – Representation of components in VFFO studies	43
Table 13 – Types of approach to perform FFO studies	52
Table 14 – Source side parameters	69
Table 15 – Characteristics of the surge arresters	69
Table 16 – Characteristics of the shunt reactor	69
Table 17 – Capacitance of circuit-breaker	70
Table 18 – Trapped charges	70
Table 19 – System configurations	71
Table 20 – Recorded overvoltages	71
Table 21 – Number of failures for 1 000 operations	72
Table 22 – Modelling of the system	76
Table 23 – Data used for the application of the EGM	76
Table 24 – Crest-current distribution	77
Table 25 – Number of strikes terminating on the different sections of the two incoming overhead transmission lines	77
Table 26 – Parameters of GIS disruptive voltage distribution and lightning crest-current distribution	78
Table 27 – FORM risk estimations (tower footing resistance = 10 Ω)	79
Table 28 – Failure rate estimation for the GIS11	80
Table 29 – Representation of GIS components – Data of the 765 kV GIS	82
Table D.1 – Line parameters	100
Table D.2 – 400 /220/33 kV transformer	101
Table D.3 – 220 /13,8 kV transformer	101
Table D.4 – Points of current and flux of 400 /220/33 kV transformer	101
Table D.5 – Points of current and flux of 220 /13,8 kV transformer	101
Table D.6 – Points of current and flux of 400 kV /150 MVA	102
Table E.1 – Parameters of the power supply	105

Table E.2 – Standard deviation and U_{50M} for different lengths (SIWV = 1 050 kV).....	108
Table E.3 – Standard deviation and U_{50M} for different lengths (SIWV = 950 kV).....	108
Table E.4 – Standard deviation and U_{50M} for different lengths (SIWV = 850 kV).....	108
Table E.5 – Statistical overvoltages $U_{2\%}$ and $U_{10\%}$ for every considered configuration	110
Table E.6 – Risks for every considered configuration.....	111
Table E.7 – Number of dielectric breakdowns over 20 000 operations for every configuration	112

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSULATION CO-ORDINATION –**Part 4: Computational guide to insulation co-ordination
and modelling of electrical networks**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60071-4, which is a technical report, has been prepared by IEC technical committee 28: Insulation co-ordination.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
28/156/DTR	28/158/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard
- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this technical report may be issued at a later date.

INSULATION CO-ORDINATION –

Part 4: Computational guide to insulation co-ordination and modelling of electrical networks

1 Scope and object

This technical report gives guidance on conducting insulation co-ordination studies which propose internationally recognized recommendations

- for the numerical modelling of electrical systems, and
- for the implementation of deterministic and probabilistic methods adapted to the use of numerical programmes.

Its object is to give information in terms of methods, modelling and examples, allowing for the application of the approaches presented in IEC 60071-2, and for the selection of insulation levels of equipment or installations, as defined in IEC 60071-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-1:1993, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60071-2:1996, *Insulation co-ordination – Part 2: Application guide*

IEC 60076-8:1997, *Power transformers – Part 8: Application guide*

IEC 60099-4:1991, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*¹

IEC 61233:1994, *High-voltage alternating current circuit-breakers – Inductive load switching*

3 Terms and definitions

For the purposes of this document, the following terms and definitions, in addition to those contained in IEC 60071-1, apply.

NOTE Certain references are taken from the IEC Multilingual Dictionary[1]².

¹ A consolidated edition exists, published in 2001, which incorporates the current edition, plus its amendment 1 (1998) and amendment 2 (2001).

² References in square brackets refer to the bibliography.