
**Nuclear facilities — Criteria for the design
and the operation of containment and
ventilation systems for nuclear reactors**

*Installations nucléaires — Critères pour la conception et l'exploitation
des systèmes de confinement et de ventilation des réacteurs nucléaires*



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.



COPYRIGHT PROTECTED DOCUMENT

© ISO 2010

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction.....	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Functions ensured by the ventilation system	6
4.1 General	6
4.2 Main functions	7
5 Architecture and description of the different ventilation systems	8
5.1 Ventilation of the volumes within the primary containment envelope	8
5.2 Ventilation of the volumes located within the secondary confinement	10
5.3 Ventilation of the volumes located outside the secondary confinement	10
5.4 Miscellaneous ventilation systems not connected with containment envelopes	11
6 Safety aspects for ventilation systems	11
6.1 General principles	11
6.2 Risk assessment procedure — General.....	12
6.3 Risk assessment procedure for severe accidents.....	14
7 Requirements for the design of ventilation systems.....	15
7.1 Confinement of radioactive material	16
7.2 Filtration	33
7.3 Reactor specificities.....	35
8 Management of specific risks	38
8.1 Control of combustible gases in the reactor building.....	38
8.2 Management of ambient conditions	39
8.3 Prevention of risks linked to releases of heat, gases or toxic vapours	41
8.4 Prevention of risks linked to the deposition of matter in ventilation ducts	41
8.5 Prevention of fire hazard	42
8.6 Consideration of external hazards	45
9 Dispositions concerning the management and the operation of the ventilation systems.....	46
9.1 Organization and operating procedures.....	46
9.2 Technical operating instructions	46
9.3 Operational management issues	47
9.4 Test procedures and maintenance	47
9.5 Monitoring of the ventilation system.....	50
9.6 Control of the ventilation system to prevent fire hazards.....	51
10 Control and instrumentation	53
10.1 Control	53
10.2 Instrumentation	53
10.3 Alarms.....	54
Annex A (informative) Typical radioactive products in nuclear reactors.....	55
Annex B (informative) Examples of general confinement concepts for nuclear power reactors.....	58
Annex C (informative) Examples of safety classification for nuclear power reactors.....	64
Annex D (informative) Examples of classification of working areas according to radiological contamination hazard	66

Annex E (informative) Example of classification of types of ventilation, according to radiological contamination hazard — Recommended ventilation configurations68

Annex F (informative) Existing requirements for aerosol filters73

Annex G (informative) Examples of loads to consider during the design of NPP ventilation systems.....78

Annex H (informative) Typical values of leaktightness for containment and ventilation systems and periodicities of associated controls79

Annex I (informative) Primary containment envelope status81

Bibliography82

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 26802 was prepared by Technical Committee ISO/TC 85, *Nuclear energy*, Subcommittee SC 2, *Radiological protection*.

Introduction

Containment and ventilation systems of nuclear power plants (NPPs) and research reactors ensure the security of such installations in order to protect the workers, the public and the environment from the dissemination of radioactive contamination originating from the operations of these installations.

This International Standard applies specifically to systems of confinement and ventilation systems for the confinement areas of reactors and their specialized buildings (such as command centres and particular areas for air purging and conditioning). This International Standard is complementary to ISO 17873, which applies mainly to nuclear fuel cycle installations (e.g. reprocessing plants, nuclear fuel fabrication and examination laboratories, plutonium handling facilities) and to radioactive waste storage, research facilities and auxiliary buildings of nuclear reactors.

Nuclear facilities — Criteria for the design and the operation of containment and ventilation systems for nuclear reactors

1 Scope

This International Standard specifies the applicable requirements related to the design and the operation of containment and ventilation systems of nuclear power plants and research reactors, taking into account the following.

For nuclear power plants, this International Standard addresses only reactors that have a secondary confinement system based on International Atomic Energy Agency (IAEA) recommendations (see Reference [10]).

For research reactors, this International Standard applies specifically to reactors for which accidental situations can challenge the integrity or leak-tightness of the containment barrier, i.e. in which a high-pressure or high-temperature transient can occur and for which the isolation of the containment building and the shut-off of the associated ventilation systems of the containment building is required.

For research reactors in which the increase of pressure or temperature during accidental situations will not damage the ventilation systems, the requirements applicable for the design and the use of ventilation systems are given in ISO 17873. However, the requirements of this International Standard can also be applied.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 10648-2, *Containment enclosures — Part 2: Classification according to leak tightness and associated checking methods*

ISO 17873, *Nuclear facilities — Criteria for the design and operation of ventilation systems for nuclear installations other than nuclear reactors*

ICRP 103, *The 2007 Recommendations of the International Commission on Radiological Protection*, ICRP Publication 103, Annals of the ICRP, 37 (2-4), Elsevier

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 Accident

3.1.1

design basis accident

DBA

accident conditions against which a facility is designed according to established design criteria, and for which the damage to the fuel and the release of radioactive material are kept within authorized limits

3.1.2

beyond-design basis accident

BDBA

accident conditions more severe than a design basis accident

3.1.3

severe accident

accident conditions more severe than a design basis accident and involving significant core degradation

3.2

aerosol

solid particles and liquid droplets of all dimensions in suspension in a gaseous fluid

3.3

air exchange rate

ratio between the ventilation air flow rate of a containment enclosure or a compartment, during normal operating conditions, and the volume of this containment enclosure or compartment

3.4

air conditioning

arrangements that allow sustaining a controlled atmosphere (temperature, humidity, pressure, dust levels, gas content, etc.) in a defined volume

3.5

balancing damper

control valve

adjustable device inserted in an aerodynamic duct allowing balancing of the fluid flow and/or the pressure of the fluid during plant operation

3.6

barrier

structural element that defines the physical limits of a volume with a particular radiological environment and that prevents or limits releases of radioactive substances from this volume

EXAMPLE Nuclear fuel cladding, primary circuit, containment building of a nuclear reactor, containment walls of auxiliary buildings, filters for some cases.

3.7

cell

shielded enclosure

shielding structure, of fairly large dimensions, possibly leak-tight

See **containment enclosure** (3.10).

NOTE It is often more practicable to limit the spread of a fire by using fire-resistant walls, and to prevent the spread of contamination in the adjacent volumes.

3.8**containment/confinement**

arrangement allowing users to maintain separate environments inside and outside an enclosure, blocking the movement between them of process materials and substances resulting from physical and chemical reactions that are potentially harmful to workers, to the public, to the external environment, or for the handled products

3.9**containment compartment****CC**

compartment of which the walls are able to contain radioactive substances that would be generated by any plausible fire that breaks out in one of the fire compartments included

NOTE It is often more practicable to limit the spread of a fire by using fire-resistant walls, and to prevent the spread of contamination in the adjacent volumes.

3.10**containment enclosure**

enclosure designed to prevent either the leakage of products contained in the pertinent internal environment into the external environment, or the penetration of substances from the external environment into the internal environment, or both simultaneously

See **cell** (3.7).

NOTE This is a generic term used to designate all kinds of enclosures, including glove boxes, leak-tight enclosures and shielded cells equipped with remotely operated devices.

3.11**containment envelope**

volume allowing the enclosure, and thus the isolation from the environment, of those structures, systems and components whose failure can lead to an unacceptable release of radionuclides

3.12**containment/confinement system**

system constituted of a coherent set of physical barriers and/or dynamic systems intended to confine radioactive substances in order to ensure the safety of the workers and the public and the protection of the environment and to avoid releases of radioactive materials in the environment

NOTE According to IAEA definitions, a containment system concerns the containment structure and the associated systems with the functions of isolation, energy management, and control of radionuclides and combustible gases. This containment system also protects the reactor against external events and provides radiation shielding during operational states and accident conditions. These two last functions are not described in this International Standard, due to the absence of link with the ventilation systems.

3.13**contamination**

presence of radioactive substances on or in a material or a human body or any place where they are undesirable or can be harmful

3.14**decontamination factor**

measure of the efficiency achieved by a filtration system and corresponding to the ratio of the radiological contents of the inlet and outlet of the filtration system

3.15**discharge stack**

duct (usually vertical) at the termination of a system, from which the air is discharged to the atmosphere after control

3.16

dynamic confinement

action allowing, by maintaining a preferential air flow circulation, the limitation of back-flow between two areas or between the inside and outside of an enclosure, in order to prevent radioactive substances being released from a given physical volume

3.17

event

unintended occurrence of a hazard leading to potential safety consequences for the plant and in particular for containment systems

NOTE An event can be internal or external to the plant.

EXAMPLE 1 Internal events:

- human errors;
- loss of coolant accidents (LOCA);
- failures in steam piping systems;
- steam generator tube rupture;
- leakage or failure of a system carrying radioactive fluid;
- fuel handling accident;
- loss of electric power;
- internal missile or explosion;
- fire;
- internal flooding.

EXAMPLE 2 External events:

- aircraft crash;
- external explosion;
- earthquake;
- flood or drought;
- winds and tornados;
- extreme temperature (high and low).

3.18

filter

device intended to trap particles suspended in gases or to trap gases themselves

NOTE A particle filter consists of a filtering medium, generally made of a porous or fibrous material (glass fibre or paper) fixed within a frame or casing. During the manufacturing process, the filter is mounted in a leak-tight manner in this frame, using a lute. Gas or vapour filters are generally found in physical or chemical process units where the primary aim is to trap certain gases. They cover in particular iodine traps (activated charcoal).

3.19

fire area

volume comprising one or more rooms or spaces, surrounded by boundaries (geographical separation) constructed to prevent the spreading of fire to or from the remainder building for a period of time allowing the extinction of the fire

3.20**fire compartment****FC**

reference volume delimited by construction elements for which fire resistance has been chosen according to the plausibility that a fire could break out within this volume or penetrate into it

3.21**fire damper****fire blocking valve**

device that is designed to prevent, generally by automatic action under specified conditions, the ingress of fire through a duct or through the walls of a room

3.22**fire load**

heat energy that can be released in the event of a fire involving the whole combustible contents of a volume, including the surfaces of the walls, partitions, floors and ceilings

3.23**gas cleaning****scrubbing**

action that consists of decreasing the content of undesirable constituents in a fluid

EXAMPLE Aerosol filtration, iodine trapping or decay storage of gases.

3.24**iodine trap**

scrubbing device, usually based on activated charcoal, intended to remove volatile radioactive components of radioactive iodine from the air or the ventilation gases

3.25**load**

physical static or dynamic phenomena that impact the containment systems during plant life or which can be associated with postulated internal or external events, or postulated accidents

3.26**negative pressure****depression**

difference in pressure between the pressure of a given volume, which is maintained lower than the pressure in a reference volume or the external ambient pressure

3.27**negative pressure system**

regulated ventilation system, which ensures a negative pressure between the ventilated area and an adjoining zone or the external ambient pressure

3.28**off-gas treatment system**

system often associated with the primary circuit, that permits a decrease in the gaseous effluent inventory prior to its discharge in the atmosphere

NOTE This system might or might not be associated with the room's ventilation systems.

3.29**prefilter**

filter fitted upstream from the main air filters to minimize, by removal of large particles, the dust burden on the latter

3.30**pressure drop**

pressure loss in an air stream due to its passing through a section of ductwork or a filter or fittings