



NATIONAL BOARD INSPECTION CODE

INSTALLATION

2021

PART
I



DIAMOND

ANNIVERSARY

NATIONAL BOARD INSPECTION CODE

2021 EDITION

DATE OF ISSUE — JULY 1, 2021


This code was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory and Jurisdictional agencies, and the public-at-large.

The National Board does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

The National Board does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code.

The National Board accepts responsibility for only those interpretations issued in accordance with governing National Board procedures and policies that preclude the issuance of interpretations by individual committee members.



The above National Board symbols are registered with the US Patent Office.

“National Board” is the abbreviation for The National Board of Boiler and Pressure Vessel Inspectors.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

All charts, graphs, tables, and other criteria that have been reprinted from the *ASME Boiler and Pressure Vessel Code*, Sections I, IV, VIII, and X are used with the permission of the American Society of Mechanical Engineers. All Rights Reserved.

Library of Congress Catalog Card No. 52-44738
 Printed in the United States of America
 All Rights Reserved

www.NBBI.org

Copyright © 2021 by
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS
 All rights reserved
 Printed in U.S.A.

PART 1 — INSTALLATION

TABLE OF CONTENTS

Introduction	IX
Foreword	XIII
Personnel	XV
 Section 1	 General Guidelines
1.1	Scope 1
1.2	Purpose 1
1.3	Application of these Rules 1
1.4	Certification, Inspection, and Jurisdictional Requirements 1
1.4.1	Responsibility 1
1.4.2	Equipment Certification 2
1.4.3	Jurisdictional Review 2
1.4.4	Inspection 2
1.4.5	Boiler Installation Report 2
1.4.5.1	Boiler Installation Report Form 3
1.4.5.1.1	Guide for Completing National Board Boiler Installation Report 3
1.5	Change of Service 7
1.6	General Requirements 7
1.6.1	Supports, Foundations, and Settings 7
1.6.2	Structural Steel 7
1.6.3	Exit 7
1.6.4	Ladders and Runways 7
1.6.5	Fuel 8
1.6.6	Ventilation and Combustion Air 8
1.6.7	Lighting 9
1.6.8	Chimney or Stack 9
1.6.9	Carbon Monoxide (CO) Detector/Alarm 9
1.6.10	Testing and Final Acceptance 9
 Section 2	 Power Boilers
2.1	Scope 10
2.2	Definitions 10
2.3	General Requirements 10
2.3.1	Supports, Foundations, and Settings 10
2.3.2	Structural Steel 10
2.3.3	Clearances 10
2.4	Equipment Room Requirements 10
2.4.1	Exit 10
2.4.2	Ladders and Runways 11
2.4.3	Drains 11
2.4.4	Water (Cleaning) 11
2.5	Source Requirements 11
2.5.1	Feedwater 11
2.5.1.1	Volume 11
2.5.1.2	Connection 11
2.5.1.3	Pumps 12
2.5.1.4	Valves 12
2.5.2	Fuel 13
2.5.3	Electrical 13
2.5.3.1	Wiring 13
2.5.3.2	Remote Emergency Shutdown Switches 13
2.5.3.3	Controls and Heat-Generating Apparatus 13
2.5.4	Ventilation and Combustion Air 14
2.5.5	Lighting 14
2.5.6	Emergency Valves and Controls 14

2.6	Discharge Requirements	14
2.6.1	Chimney or Stack	14
2.6.2	Ash Removal	14
2.6.3	Drains	14
2.6.3.1	Connection	14
2.6.3.2	Pressure Rating	14
2.6.3.3	Parts	15
2.7	Operating Systems	15
2.7.1	Breeching and Dampers	15
2.7.2	Burners and Stokers	15
2.7.3	Steam Supply	15
2.7.4	Condensate and Return	16
2.7.5	Blowoff	16
2.8	Controls and Gages	17
2.8.1	Water	17
2.8.2	Pressure Gage	18
2.8.2.1	Connection	18
2.8.3	Temperature	19
2.8.4	Pressure Control	19
2.8.5	Automatic Low-Water Fuel Cutoff and/or Water Feeding Device for Stream or Vapor System Boilers	19
2.9	Pressure Relief Valves	20
2.9.1	Valve Requirements — General	20
2.9.1.1	Number	20
2.9.1.2	Location	20
2.9.1.3	Capacity	21
2.9.1.4	Set Pressure	22
2.9.2	Forced-Flow Steam Generator	23
2.9.3	Superheaters	23
2.9.4	Economizers	24
2.9.5	Pressure-Reducing Valves	24
2.9.6	Installation and Discharge Requirements	24
2.10	Testing and Acceptance	25
2.10.1	General	25
2.10.2	Pressure Test	26
2.10.3	Nondestructive Examination	26
2.10.4	System Testing	26
2.10.5	Final Acceptance	26
2.10.6	Boiler Installation Report	26
2.11	Tables and Figures	26
Section 3	Steam Heating Boilers, Hot-Water Heating Boilers, Hot-Water Supply Boilers, and Potable Water Heaters	27
3.1	Scope	27
3.2	Definitions	27
3.3	General Requirements	27
3.3.1	Supports	27
3.3.1.1	Methods of Support for Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	27
3.3.2	Settings	29
3.3.3	Structural Steel	29
3.3.4	Clearances	29
3.4	Equipment Room Requirements	29
3.4.1	Exit	29
3.4.2	Ladders and Runways	29
3.5	Source Requirements	30
3.5.1	Water	30
3.5.2	Fuel	30
3.5.3	Electrical	30

3.5.3.1	Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers.....	30
3.5.3.2	Potable Water Heaters	30
3.5.3.3	Controls and Heat Generating Apparatus	31
3.5.4	Ventilation and Combustion Air	31
3.5.5	Lighting	31
3.5.6	Emergency Valves and Controls	31
3.6	Discharge Requirements.....	31
3.6.1	Chimney or Stack	31
3.6.2	Ash Removal	31
3.6.3	Drains	32
3.7	Operating Systems	32
3.7.1	Oil Heaters	32
3.7.2	Breeching and Dampers	32
3.7.3	Burners and Stokers	32
3.7.4	Feedwater, Makeup Water, and Water Supply	32
3.7.5	Stop Valves	33
3.7.5.1	Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	33
3.7.5.2	Potable Water Heaters	37
3.7.6	Return Pipe Connections	38
3.7.7	Bottom Blowoff and Drain Valves	38
3.7.7.1	Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	38
3.7.7.2	Potable Water Heaters	39
3.7.8	Modular Steam Heating and Hot-Water Heating Boilers	40
3.7.8.1	Individual Modules	40
3.7.8.2	Assembled Modular Boilers	40
3.7.9	Provisions for Thermal Expansion	40
3.7.9.1	Expansion Tanks and Piping for Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	40
3.7.9.2	Expansion Tanks and Piping For Potable Water Heaters	43
3.8	Instruments, Fittings, and Controls	44
3.8.1	Steam Heating Boilers	44
3.8.1.1	Steam Gages	44
3.8.1.2	Water-Gage Glasses	44
3.8.1.3	Water Column and Water Level Control Pipes	45
3.8.1.4	Pressure Control	45
3.8.1.5	Automatic Low-Water Fuel Cutoff and/or Water Feeding Device	46
3.8.1.6	Modular Steam Heating Boilers	46
3.8.1.7	Instruments, Fittings, and Controls Mounted Inside Boiler Jackets	46
3.8.2	Hot-Water Heating or Hot-Water Supply Boilers	46
3.8.2.1	Pressure or Altitude Gages	46
3.8.2.2	Thermometers	47
3.8.2.3	Temperature Control	47
3.8.2.4	Low-Water Fuel Cutoff	47
3.8.2.5	Modular Hot-Water Heating Boilers	48
3.8.2.6	Instruments, Fittings, and Controls Mounted Inside Boiler Jackets.....	48
3.8.3	Potable Water Heaters	48
3.8.3.1	Temperature Controls	48
3.8.3.2	Thermometer	48
3.9	Pressure Relief Valves	48
3.9.1	Pressure Relief Valve Requirements — General	49
3.9.1.1	Installation of Pressure Relief Valves for Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	49
3.9.1.1.1	Permissible Installation	49
3.9.1.1.2	Requirements for Common Connections for Two or More Valves	49
3.9.1.2	Threaded Connections	49
3.9.1.3	Prohibited Installations	49
3.9.1.4	Use of Shutoff Valves Prohibited	49
3.9.1.5	Pressure Relief Valve Discharge Piping	50
3.9.1.6	Temperature and Pressure Relief Valves	50

3.9.2	Pressure Relief Valve Requirements for Steam Heating Boilers	50
3.9.3	Pressure Relief Valve Requirements for Hot-Water Heating or Hot-Water Supply Boilers	51
3.9.4	Pressure Relief Valve Requirements for Potable Water Heaters	52
3.9.4.1	Installation	52
3.9.4.2	Permissible Installations	52
3.9.4.3	Requirements for Common Connection for Two or More Valves	53
3.9.4.4	Threaded Connections	53
3.9.4.5	Prohibited Installations	53
3.9.4.6	Use of Shutoff Valves Prohibited	53
3.9.4.7	Temperature and Pressure Relief Valve Discharge Piping	53
3.9.5	Pressure Relief Valves for Tanks and Heat Exchangers	54
3.9.5.1	Steam to Hot-Water Supply	54
3.9.5.2	High-Temperature Water to Water Heat Exchanger	54
3.9.5.3	High-Temperature Water to Steam Heat Exchanger	54
3.10	Testing and Acceptance	54
3.10.1	Pressure Test	54
3.10.2	Final Acceptance	54
3.10.3	Boiler Installation Report	54
3.11	Tables and Figures	55
Section 4	Pressure Vessels	56
4.1	Scope	56
4.2	Definitions	56
4.3	General Requirements	56
4.3.1	Supports	56
4.3.2	Clearances	56
4.3.3	Piping	56
4.3.4	Bolting	56
4.4	Instruments and Controls	56
4.4.1	Level Indicating Devices	56
4.4.2	Pressure Indicating Devices	57
4.5	Pressure Relief Devices	57
4.5.1	Device Requirements	57
4.5.2	Number of Devices	57
4.5.3	Location	57
4.5.4	Capacity	57
4.5.5	Set Pressure	58
4.5.6	Installation and Discharge Piping Requirements	58
4.6	Testing and Acceptance	59
4.7	Requirements for Hot Water Storage Tanks/Potable Hot Water Storage Tanks	59
4.7.1	Supports	60
4.7.2	Clearance and Accessibility	60
4.7.3	Temperature and Pressure Relief Devices	60
4.7.4	Thermometers	60
4.7.5	Shut Off Valves	60
4.7.6	Testing and Acceptance	60
Section 5	Piping	61
5.1	Scope	61
5.2	General Requirements	61
5.2.1	Additions to Existing Piping	61
5.2.2	Proximity to Other Equipment and Structures	61
5.2.3	Flanges and Other Non-Welded Joints	61
5.2.4	Valves	61
5.2.5	Materials	62
5.2.6	Hangers and Supports	62
5.2.7	Protection and Cleaning	62
5.2.8	Welding and Brazing	62
5.2.9	Bolting	62

5.3	Pressure Relief Devices	62
5.3.1	Device Requirements	62
5.3.2	Number of Devices	63
5.3.3	Location	63
5.3.4	Capacity	63
5.3.5	Set Pressure	63
5.3.6	Inlet and Discharge Piping Requirements	63
5.4	Examination, Inspection, and Testing	64
Section 6	Supplements	65
Supplement 1	Installation of Yankee Dryers (Rotating Pressure Vessels) with Finished Shell Outer Surfaces	65
S1.1	Scope	65
S1.2	Assessment of Installation.....	66
S1.3	Determination of Allowable Operating Parameters	68
S1.4	ASME Code Primary Membrane Stress Criteria	69
S1.5	Pressure Testing.....	69
S1.6	Nondestructive Examination.....	70
Supplement 2	Pressure Relief Valves on the Low-Pressure Side of Steam Pressure Reducing Valves	71
S2.1	Scope	71
S2.2	Pressure Relief Valve Capacity	71
S2.3	Calculation of Pressure Relief Valve Relieving Capacity	71
S2.4	Steam Flow When Flow Coefficients Are Not Known	79
S2.5	Two-Stage Pressure Reducing Valve Stations	79
Supplement 3	Installation of Liquid Carbon Dioxide Storage Vessels	81
S3.1	Scope	81
S3.2	General Requirements Storage Tank Location	81
S3.2.1	General Requirements (Enclosed and Unenclosed Areas)	81
S3.2.2	Unenclosed Area LCDSV Installations	82
S3.2.3	Enclosed Area LCDSV Installations	82
S3.3	Fillbox Location/Safety Relief/Vent Valve Circuit Termination	82
S3.4	Gas Detection Systems	83
S3.5	Signage	83
S3.6	Valves, Piping, Tubing, and Fittings	83
S3.6.1	System Description	86
Supplement 4	Installation of Biomass (Wood/Solid Fuel) Fired Boilers	89
S4.1	Scope	89
S4.2	Purpose	89
S4.3	Determination of Allowable Operating Parameters	89
S4.4	General Requirements	90
S4.5	Fuel System Requirements and Controls.....	90
S4.6	Combustion Requirements.....	91
Supplement 5	Installation of Thermal Fluid Heaters	93
S5.1	Scope	93
S5.2	Definitions.....	93
S5.3	General Requirements	93
S5.3.1	Supports, Foundations, and Settings	93
S5.3.2	Structural Steel	93
S5.3.3	Settings	93
S5.3.4	Clearances	93
S5.4	Thermal Fluid Heater Room Requirements.....	94
S5.4.1	Exit	94
S5.4.2	Ladders and Runways.....	94

S5.5	System Requirements	94
S5.5.1	Thermal Liquids (Heat Transfer Fluids)	94
S5.5.2	Expansion	94
S5.5.3	Connection	95
S5.5.4	Circulating Pump	95
S5.5.5	Piping and Valves	95
S5.5.6	Fuel	96
S5.5.7	Electrical	96
S5.5.8	Ventilation and Combustion Air	98
S5.5.9	Lighting	98
S5.5.10	Emergency Valves and Controls	98
S5.6	Discharge Requirements	98
S5.6.1	Chimney or Stack	98
S5.6.2	Drains	98
S5.6.3	Air Vent	98
S5.7	Overpressure Protection	98
S5.7.1	General Requirements	98
S5.7.2	Pressure Relief Valves	98
S5.7.3	Location	99
S5.7.4	Capacity	99
S5.7.5	Set Pressure	99
S5.7.6	Installation	99
S5.8	Testing and Acceptance	100
S5.8.1	General	100
S5.8.2	Pressure Test	101
S5.8.3	Nondestructive Examination	101
S5.8.4	System Testing	101
S5.8.5	Final Acceptance	101
S5.8.6	Installation Report	101
Supplement 6	Special Requirements for the Installation of Condensing Boilers	102
S6.1	Scope	102
S6.2	Determination of Allowable Operating Parameters	102
S6.3	General Requirements	102
S6.4	Flue Gas Venting System Piping Requirements	102
S6.5	Sealed Combustion System Requirements	102
S6.6	Condensate Drain System Requirements	103
Supplement 7	Installation of Graphite Pressure Equipment	104
S7.1	Scope	104
S7.2	Glossary of Terms	104
S7.3	General Requirements	104
S7.3.1	Receiving and Initial Inspection of Graphite Pressure Equipment	104
S7.3.2	Equipment Parameters/Clearances/Movement	105
S7.3.3	Supports/Foundations	105
S7.3.4	Piping Connections	105
S7.3.5	Instruments and Controls	106
S7.3.6	Post-Installation Activities	106
Supplement 8	Installation of Pressure Vessels for Human Occupancy (PVHOs)	107
S8.1	Scope	107
S8.2	General	107
S8.3	Documentation, Registration, and Regulatory Requirements	107
S8.4	PVHO System Configuration and Installation	108
S8.5	Responsibilities	110
S8.6	Other Codes, Standards, and References	111

Supplement 9	High-Temperature Water Boilers	112
S9.1	Scope	112
S9.2	Installation Requirements.....	112
Section 7	NBIC Policy for Metrication	113
7.1	General	113
7.2	Equivalent Rationale	113
7.3	Procedure for Conversion	113
7.4	Referencing Tables	114
Section 8	Preparation of Technical Inquiries to the <i>National Board</i>	
	<i>Inspection Code Committee</i>	119
8.1	Introduction	119
8.2	Inquiry Format	119
8.3	Code Revisions or Additions	120
8.4	Code Interpretations	120
8.5	Submittals	121
Section 9	Glossary of Terms	122
9.1	Definitions	122
Section 10	NBIC Approved Interpretations	129
10.1	Scope	129
Section 11	Index	140

INTRODUCTION

It is the purpose of the *National Board Inspection Code* (NBIC) to maintain the integrity of pressure-retaining items by providing rules for post-construction activities including installation, and after the items have been placed into service, by providing rules for inspection and repair and alteration, thereby ensuring that these items may continue to be safely used.

The NBIC is intended to provide rules, information, and guidance to manufacturers, Jurisdictions, inspectors, owner-users, installers, contractors, and other individuals and organizations performing or involved in post-construction activities, thereby encouraging the uniform administration of rules pertaining to pressure retaining items.

SCOPE

The NBIC recognizes three important areas of post-construction activities where information, understanding, and following specific requirements will promote public and personal safety. These areas include:

- Installation
- Inspection
- Repairs and Alterations

The NBIC provides rules, information, and guidance for post-construction activities, but does not provide details for all conditions involving pressure-retaining items. Where complete details are not provided in this code, the code user is advised to seek guidance from the Jurisdiction and from other technical sources.

The words shall, should, and may are used throughout the NBIC and have the following intent:

- Shall – action that is mandatory and required.
- Should – indicates a preferred but not mandatory means to accomplish the requirement unless specified by others, such as the Jurisdiction.
- May – permissive, not required or a means to accomplish the specified task.

ORGANIZATION

The NBIC is organized into four parts to coincide with specific post-construction activities involving pressure-retaining items. Each part provides general and specific rules, information, and guidance within each applicable post-construction activity. Other NBIC parts or other published standards may contain additional information or requirements needed to meet the rules of the NBIC. Specific references are provided in each part to direct the user where to find this additional information. NBIC parts are identified as:

- Part 1, Installation – This part provides requirements and guidance to ensure all types of pressure-retaining items are installed and function properly. Installation includes meeting specific safety criteria for construction, materials, design, supports, safety devices, operation, testing, and maintenance.
- Part 2, Inspection – This part provides information and guidance needed to perform and document inspections for all types of pressure-retaining items. This part includes information on personnel safety, non-destructive examination, tests, failure mechanisms, types of pressure equipment, fitness for service, risk-based assessments, and performance-based standards.
- Part 3, Repairs and Alterations – This part provides requirements and guidance to perform, verify, and document acceptable repairs or alterations to pressure retaining items regardless of code of construction. Alternative methods for examination, testing, heat treatment, etc., are provided when the original code of construction requirements cannot be met. Specific acceptable and proven repair methods are also provided.
- Part 4, Pressure Relief Devices – This part provides information and guidance to ensure pressure relief devices are installed properly, information and guidance needed to perform and document inspections for pressure relief devices, and information and guidance to perform, verify, and document acceptable repairs to pressure relief devices.

Each NBIC part is divided into major sections as outlined in the Table of Contents.

Tables, charts, and figures provide relevant illustrations or supporting information for text passages, and are designated with numbers corresponding to the paragraph they illustrate or support within each section. Multiple tables, charts, or figures referenced by the same paragraph will have additional letters reflecting the order of reference. Tables, charts, and figures are located in or after each major section within each NBIC part.

TEXT IDENTIFICATION AND NUMBERING

Each page in the text will be designated in the top header with the publication's name, part number, and part title. The numbering sequence for each section begins with the section number followed by a dot to further designate major sections (e.g., 1.1, 1.2, 1.3). Major sections are further subdivided using dots to designate subsections within that major section (e.g., 1.1.1, 1.2.1, 1.3.1). Subsections can further be divided as necessary. Paragraphs under sections or subsections shall be designated with small letters in parenthesis (e.g., a), b), c)) and further subdivided using numbers in parenthesis (e.g., 1), 2), 3)).

Subdivisions of paragraphs beyond this point will be designated using a hierarchical sequence of letters and numbers followed by a dot.

Example: 2.1 Major Section
 2.1.1 Section
 2.1.2 Section
 2.1.2. Subsection
 a) paragraph
 b) paragraph
 1) subparagraph
 2) subparagraph
 a. subdivisions
 1. subdivisions
 2. subdivisions
 b. subdivisions
 1. subdivisions
 2. subdivisions

Tables and figures will be designated with the referencing section or subsection identification. When more than one table or figure is referenced in the same section or subsection, letters or numbers in sequential order will be used following each section or subsection identification.

SUPPLEMENTS

Supplements are contained in each part of the NBIC to provide requirements and guidance only pertaining to a specific type of pressure-retaining item (e.g., Locomotive Boilers, Historical Boilers, Graphite Pressure Vessels.) Supplements follow the same numbering system used for the main text only preceded by the letter "S." Each page of the supplement will be tabbed to identify the supplement number.

EDITIONS

Editions, which include revisions and additions to this code, are published every two years. Editions are permissive on the date issued and become mandatory six months after the date of issue.

CODE STAMPING

ASME Code "Stamping" referenced throughout the NBIC includes the ASME Boiler and Pressure Vessel Code Symbol Stamps used for conformity assessment prior to the 2010 edition/2011 addendum and the equivalent ASME Certification Mark with Designator required to meet the later editions of the ASME Boiler and Pressure Vessel Code Sections. When other construction codes or standards are utilized for repairs or alterations, stamping shall mean the identification symbol stamp required by that code or standard.