



Standard for Smoke Control Systems

2018



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA[®] codes, standards, recommended practices, and guides ("NFPA Standards"), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A \triangle before a section number indicates that words within that section were deleted and a \triangle to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the \triangle symbol. Where one or more sections were deleted, a • is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that NFPA Standards may be amended from time to time through the issuance of a Tentative Interim Amendment (TIA) or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, go to www.nfpa.org/docinfo to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 13). The document information page provides up-to-date document-specific information as well as postings of all existing TIAs and Errata. It also includes the option to register for an "Alert" feature to receive an automatic email notification when new updates and other information are posted regarding the document.

ISBN: 978-145591902-4 (PDF) ISBN: 978-145591903-1 (*Peril

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes[®] Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards ("the ANSI Patent Policy"), and hereby gives the following notice pursuant to that policy:

NOTICE: The user's attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term "adoption by reference" means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2017 National Fire Protection Association®. All Rights Reserved.

NFPA® 92

Standard for

Smoke Control Systems

2018 Edition

This edition of NFPA 92, *Standard for Smoke Control Systems*, was prepared by the Technical Committee on Smoke Management Systems. It was issued by the Standards Council on November 10, 2017, with an effective date of November 30, 2017, and supersedes all previous editions.

This edition of NFPA 92 was approved as an American National Standard on November 30, 2017.

Origin and Development of NFPA 92

The NFPA Standards Council established the Technical Committee on Smoke Management Systems in 1985 and charged it with addressing the need for guidelines and materials on smoke management in buildings. The Committee's first document, NFPA 92A, *Recommended Practice for Smoke-Control Systems*, was published in 1988 and addressed smoke control utilizing barriers, airflows, and pressure differentials so as to confine the smoke of a fire to the zone of fire origin to maintain a tenable environment in other zones. The complex problem of maintaining tenable conditions within large zones of fire origin such as atria and shopping malls represented a more difficult issue in terms of the physics involved and thus was reserved for another document, NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*, first published in 1991.

Between 1991 and 2009, NFPA 92A and NFPA 92B were separately maintained. In 2006, NFPA 92A was rewritten as a standard with mandatory provisions regarding design, installation, and testing of smoke-control systems and was renamed *Smoke-Control Systems Utilizing Barriers and Pressure Differences*. In 2005 and 2006, both documents were reorganized to comply with the *Manual of Style for NFPA Technical Committee Documents*. Both documents eventually contained many of the same requirements for design objectives, activation, and installation.

In the Annual 2011 revision cycle, NFPA 92A and NFPA 92B were withdrawn and replaced with a new document, NFPA 92, *Standard for Smoke Control Systems*. NFPA 92 was created using requirements from both of the original documents, removing duplicate provisions and making numerous editorial changes. The new document used the term *smoke control systems* to address both containment and management systems. With the consolidation effort, the new standard covered the following topics: design of smoke management systems and calculations, design of smoke containment systems, design of stairwell pressurization systems, and testing requirements.

The 2015 edition includes editorial revisions and new requirements addressing draft curtain materials.

New to the 2018 edition of NFPA 92 is the addition of requirements regarding the verification of dedicated smoke control equipment through use of the weekly self-test function. A new annex on tenability was added to provide guidelines for designers to assess tenable conditions in spaces protected by smoke control systems, in connected spaces, and of means of egress elements during the operation of a smoke control system.

NFPA and National Fire Protection Association are registered trademarks of the National Fire Protection Association, Quincy, Massachusetts 02169.

Technical Committee on Smoke Management Systems

Allyn J. Vaughn, Chair NV5/JBA Consulting Engineers, NV [SE]

Elyahu Avidor, Tel Aviv, Israel [RT] Rep. Standards Institution of Israel Carl F. Baldassarra, Wiss Janney Elstner Associates, Inc., IL [SE] Flora F. Chen, Hayward Fire Department, California, CA [E] Richard J. Davis, FM Global, MA [I] Kevin L. Derr, U.S. Architect of the Capitol, DC [E] Kelly Eisenstein, City Of San Diego, CA [E] Michael J. Ferreira, JENSEN HUGHES, MD [SE] Donald Fess, Harvard University, MA [U] Maxwell French, Cosentini Associates, MA [SE] Brian Green, Viking Corporation, MI [M] Rep. National Fire Sprinkler Association Geoffrey Harris, Smoke and Fire Engineering Technology Ltd., United Kingdom [SE] Rep. ISO TC on Smoke and Heat Control Systems and Components David A. Killian, Walt Disney Parks & Resorts, CA [U] William E. Koffel, Koffel Associates, Inc., MD [M] Rep. AAMA Smoke Vent Task Group

Jeffrey A. Maddox, The Fire Consultants, Inc., CA [SE] Cameron J. McCartney, National Research Council of Canada, Canada [RT] James A. Milke, University of Maryland, MD [SE] Timothy J. Orris, AMCA International, Inc., IL [M] Rep. Air Movement & Control Association Thomas J. Parrish, Telgian Corporation, MI [M] Rep. Automatic Fire Alarm Association, Inc. Joseph Plati, Code Consultants, Inc., NY [SE] James R. Richardson, Lisle Woodridge Fire District, IL [E] Lawrence J. Shudak, UL LLC, IL [RT] Deo Suriya Supanavongs, Honeywell International Inc., IL [M] Rep. National Electrical Manufacturers Association Jeffrey S. Tubbs, Arup, MA [SE] Paul G. Turnbull, Siemens Building Technologies, Inc., IL [M] Michael J Ventola, Space Age Electronics, FL [M] Stacy N. Welch, Marriott International, Inc., MD [U] Peter J. Willse, Global Asset Protection Services, LLC, CT [I]

Alternates

Sanjay Aggarwal, JENSEN HUGHES, CA [SE] (Alt. to Michael J. Ferreira)
Mark Allen Belke, Greenheck Fan Corporation, WI [M] (Alt. to Timothy J. Orris)
Diane B. Copeland, Dillon Consulting Engineers, Inc., CA [SE] (Voting Alternate)

Jason Daniels, Code Consultants, Inc., MO [SE] (Alt. to Joseph Plati)

Donald G. Goosman, Wiss Janney Elstner Associates, Inc., IL [SE] (Alt. to Carl F. Baldassarra)

Gary D. Lougheed, National Research Council of Canada, Canada [RT]

(Alt. to Cameron J. McCartney)

Zachary L. Magnone, Tyco Fire Protection Products, RI [M] (Alt. to Brian Green)

(Ålt. to Deo Suriya Supanavongs)
Andrew Neviackas, Arup, MA [SE]

(Alt. to Jeffrey S. Tubbs)

Gregory K. Shino, NV5/JBA Consulting Engineers, NV [SE]

(Alt. to Allyn J. Vaughn)

Luke C. Woods, UL LLC, MA [RT]

(Alt. to Lawrence J. Shudak)

Brittany Dawn Wright, Walt Disney Parks & Resorts, FL [U]

(Alt. to David A. Killian)

Yibing Xin, FM Global, MA [I] (Alt. to Richard J. Davis)

John H. Klote, Leesburg, VA [SE] (Member Emeritus)

Wesley Marcks, Xtralis, Inc., MA [M]

Nonvoting

Christian Norgaard Madsen, Norconsult, Norway [SE] Bent A. Borresen, Norconsult, Norway [SE] (Alt. to Christian Norgaard Madsen)

Brian J. O'Connor, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the design, installation, testing, operation, and maintenance of systems for the control, removal, or venting of heat or smoke from fires in buildings.

Contents

Chapter	1 Administration	92– 4
1.1	Scope	92– 4
1.2	Purpose.	92– 4
1.3	Retroactivity	92– 4
1.4	Equivalency.	92– 4
1.5	Units and Formulas. (Reserved)	92– 4
Chapter	2 Referenced Publications	92– 4
2.1	General.	92– 4
2.2	NFPA Publications.	92– 4
2.3	Other Publications.	92– 5
2.4	References for Extracts in Mandatory Sections	92– 5
Chapter	3 Definitions	92– 5
$3.\hat{1}$	General.	92– 5
3.2	NFPA Official Definitions.	92– 5
3.3	General Definitions	92– 5
Chapter	4 Design Fundamentals	92 – 7
4.1	Design Objectives.	92 – 7
4.2	Design Basis	92-7
4 3	Design Approaches	92-7
4.4	Design Criteria	92-7
4.5	System Operation	92 8
4.6	Stairwell Pressurization Systems	92 9
4 7	Flevator Pressurization Systems	92 9
4.8	Zoned Smoke Control	92 9
4.0	Combination of Systems	09_ 10
4 10	Vestibules	92 -10
4.11	Doors	92 –10
Chapter	5 Smoke Management Calculation	
	Procedures	92– 10
5.1	Introduction	92– 10
5.2	Design Fire	92– 10
5.3	Mass Consumption.	92– 11
5.4	Smoke Layer Calculations.	92– 12
5.5	Rate of Smoke Mass Production	92– 12
5.6	Number of Exhaust Inlets.	92– 15
5.7	Volumetric Flow Rate	92– 15
5.8	Density of Smoke	92– 16
5.9	Varying Cross-Sectional Geometries and	
	Complex Geometries.	92– 16
5.10	Opposed Airflow.	92– 16
5.11	Scaling Laws.	92– 18
Chapter	6 Building Equipment and Controls	92– 18
$6.\hat{1}$	General.	92– 18
6.2	Heating, Ventilating, and Air-Conditioning	
	(HVAC) Equipment.	92– 18
6.3	Smoke Dampers	92– 18

6.4	Smoke Control Systems.	92– 18
6.5	Energy Management.	92– 21
6.6	Materials.	92– 21
6.7	Electric Services Installation.	92– 21
Chapter	7 Smoke Control System Documentation	92– 21
7.1	Documentation Required.	92– 21
7.2	Detailed Design Report.	92– 21
7.3	Operations and Maintenance Manual.	92– 21
Chapter	8 Testing	92– 21
8.1	General	92– 21
8.2	Preliminary Building Inspections.	92– 21
8.3	Component System Testing.	92– 22
8.4	Acceptance Testing.	92– 22
8.5	Testing Documentation	92 – 94
8.6	Periodic Testing	99_ 94
0.0	Modifications	09 94
0.7	Modifications.	92- 24
Annex A	Explanatory Material	92– 24
Annex B	Predicting the Rate of Heat Release of	
	Fires	92– 45
Annex C	Computer-Based Models for Atria and	00 50
	Mails	92 – 56
Annex I	Additional Design Objectives	92– 61
Annex E	Stratification of Smoke	92– 64
Annex F	Types of Stairwell Pressurization Systems	92– 65
Annex C	HVAC Air-Handling System Types	92– 66
Annex H	Fire Fighters' Smoke Control Station (FSCS) Considerations	92– 68
Annex I	Information on Testing for Leakage Between Smoke Zones	92 – 69
Annex J	Advisory Information on Acceptance Testing	92– 70
Annex F	Example Problems Illustrating the Use of Equations	92– 71
Annex I	Comparison of Equations	92– 73
Annex M	I Tenability	92– 76
Annex N	Informational References	92– 79
Index		92– 84

92-4

NFPA 92

Standard for

Smoke Control Systems

2018 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes[®] Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex N. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex N.

Chapter 1 Administration

1.1* Scope. This standard shall apply to the design, installation, acceptance testing, operation, and ongoing periodic testing of smoke control systems.

1.2 Purpose.

1.2.1 The purpose of this standard shall be to establish requirements for smoke control systems to accomplish one or more of the following:

- Inhibit smoke from entering stairwells, means of egress, smoke refuge areas, elevator shafts, or similar areas
- (2) Maintain a tenable environment in smoke refuge areas and means of egress during the time required for evacuation
- (3) Inhibit the migration of smoke from the smoke zone

- (4) Provide conditions outside the smoke zone that enable emergency response personnel to conduct search and rescue operations and to locate and control the fire
- (5) Contribute to the protection of life and to the reduction of property loss

1.2.2 The requirements specifying the conditions under which a smoke control system shall be provided are addressed by other codes and standards.

1.2.3 Specific design objectives are established in other codes and standards.

1.3 Retroactivity.

1.3.1 Unless otherwise noted, it is not intended that the provisions of this document be applied to facilities, equipment, structures, or installations that were existing or approved for construction or installation prior to the effective date of this document.

1.3.2 In those cases where the authority having jurisdiction determines that the existing situation involves a distinct hazard to life or property, retroactive application of the provisions of this document shall be permitted.

1.3.3 Where a smoke control system is being altered, extended, or renovated, the requirements of this standard shall apply only to the work being undertaken.

1.3.4 Verification is required to ensure that new or modified systems do not adversely affect the performance of existing smoke control systems.

1.4 Equivalency. Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

1.4.1 Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

1.4.2 The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

1.5 Units and Formulas. (Reserved)

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 70[®], National Electrical Code[®], 2017 edition.

NFPA 72[®], *National Fire Alarm and Signaling Code*, 2016 edition.

NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems, 2018 edition.

NFPA 101[®], Life Safety Code[®], 2018 edition.

NFPA 110, Standard for Emergency and Standby Power Systems, 2016 edition.

NFPA 221, Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls, 2018 edition.

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.

2.3 Other Publications.

2.3.1 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 555, Standard for Fire Dampers, 2006, revised 2014.

ANSI/UL 555S, Standard for Smoke Dampers, 2014.

ANSI/UL 864, Standard for Control Units and Accessories for Fire Alarm Systems, 2014.

2.3.2 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

Δ 2.4 References for Extracts in Mandatory Sections.

NFPA 1, Fire Code, 2018 edition.

NFPA 3, Standard for Commissioning of Fire Protection and Life Safety Systems, 2018 edition.

NFPA 101[®], Life Safety Code[®], 2018 edition.

NFPA 556, Guide on Methods for Evaluating Fire Hazard to Occupants of Passenger Road Vehicles, 2016 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.4* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.5 Shall. Indicates a mandatory requirement.

3.2.6 Should. Indicates a recommendation or that which is advised but not required.

3.2.7 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase "standards development process" or "standards development activities," the term "standards, Recommended Practices, and Guides.

3.3 General Definitions.

3.3.1 Atrium. A large-volume space created by a floor opening or series of floor openings connecting two or more stories that is covered at the top of the series of openings and is used for purposes other than an enclosed stairway; an elevator hoistway; an escalator opening; or as a utility shaft used for plumbing, electrical, air-conditioning, or communications facilities. [101, 2018]

3.3.2* Ceiling Jet. A flow of smoke under the ceiling, extending radially from the point of fire plume impingement on the ceiling.

3.3.3* Design Pressure Difference. The desired pressure difference between the protected space and an adjacent space measured at the boundary of the protected space under a specified set of conditions with the smoke control system operating.

3.3.4* Draft Curtain. A fixed or automatically deployable barrier that protrudes downward from the ceiling to channel, contain, or prevent the migration of smoke.

3.3.5 Fire.

3.3.5.1 *Fuel-Limited Fire.* A fire that has a heat release rate that is controlled by the material burning.

3.3.5.2 *Steady Fire.* A fire that has a constant heat release rate.

3.3.5.3 *t-squared* (t^2) *Fire.* A fire that has a heat release rate that grows proportionally to the square of time from ignition. [See Annex B for further information on t-squared (t^2) profile fires.]

3.3.5.4 *Unsteady Fire.* A fire that has a heat release rate that varies with respect to time.

3.3.5.5 *Ventilation Limited Fire.* A fire where every object in the fire compartment is fully involved in fire and the heat release rate depends on the airflow through the openings to the fire compartment.

3.3.6* Fire Fighters' Smoke Control Station (FSCS). A system that provides graphical monitoring and manual overriding capability over smoke control systems and equipment at designated location(s) within the building for use by the fire department.

3.3.7 Growth Time (t_g) . The time interval from the time of effective ignition until the heat release rate of the fire is 1000 Btu/sec (1055 kW).

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.

3.3.8 Plugholing. The condition where air from below the smoke layer is pulled through the smoke layer into the smoke exhaust due to a high exhaust rate.

3.3.9* Plume. A column of smoke that rises above a fire.

3.3.9.1* Axisymmetric Plume. A plume that rises above a fire, does not come into contact with walls or other obstacles, and is not disrupted or deflected by airflow.

3.3.9.2* *Balcony Spill Plume.* A smoke plume that originates from a compartment fire, flows out the doorway, flows under a balcony, and flows upward after passing the balcony edge.

3.3.9.3* *Window Plume.* A plume that flows out of an opening to a room or other compartment that is involved in a ventilation limited fire.

3.3.10 Pressurized Stairwells. A type of containment smoke control system in which stair shafts are mechanically pressurized, with respect to the fire area, with outdoor air to keep smoke from contaminating them during a fire incident.

3.3.11 Registered Design Professional (RDP). An individual who is registered or licensed to practice their respective design profession as defined by the statutory requirements of the professional registration laws of the jurisdiction in which the project is to be constructed, or other professional with qualifications or credentials acceptable to the jurisdiction in which the project is to be constructed. [3, 2018]

3.3.12 Smoke. The airborne solid and liquid particulates and gases evolved when a material undergoes pyrolysis or combustion, together with the quantity of air that is entrained or otherwise mixed into the mass. [556, 2016]

3.3.12.1* *First Indication of Smoke.* The boundary between the transition zone and the smoke free air.

3.3.13* Smoke Barrier. For the purposes of this standard, a continuous membrane, either vertical or horizontal, such as a wall, floor, or ceiling assembly, that is designed and constructed to restrict the movement of smoke in conjunction with a smoke control system.

3.3.14* Smoke Containment. A smoke control method that uses mechanical equipment to produce pressure differences across smoke barriers.

3.3.15 Smoke Control Mode. A predefined operational configuration of a system or device for the purpose of smoke control.

3.3.16 Smoke Damper. A device within the air distribution system to control the movement of smoke.

3.3.17* Smoke Layer. The accumulated thickness of smoke below a physical or thermal barrier.

3.3.18* Smoke Layer Interface. The theoretical boundary between a smoke layer and the smoke-free air.

3.3.19 Smoke Management. A smoke control method that utilizes natural or mechanical systems to maintain a tenable environment in the means of egress from a large-volume space or to control and reduce the migration of smoke between the fire area and communicating spaces.

3.3.20 Smoke Refuge Area. An area of the building separated from other spaces by fire resistance-rated smoke barriers in

which a tenable environment is maintained for the period of time that such areas might need to be occupied at the time of fire.

3.3.21 Space.

3.3.21.1* *Communicating Space.* A space within a building that has an open pathway to a large-volume space such that smoke from a fire either in the communicating space or in a large-volume space can move from one to another without restriction.

3.3.21.2 *Large-Volume Space.* An uncompartmented space, generally two or more stories in height, within which smoke from a fire either in the space or in a communicating space can move and accumulate without restriction.

3.3.21.3 *Separated Spaces.* Spaces within a building that are isolated from large-volume spaces by smoke barriers.

3.3.22 Stack Effect. The vertical airflow within buildings caused by the temperature-created density differences between the building interior and exterior or between two interior spaces.

3.3.23 System.

3.3.23.1 *Compensated System.* A system that adjusts for changing conditions either by modulating supply airflows or by relieving excess pressure.

3.3.23.2* *Dedicated Smoke Control System.* Smoke control systems and components that are installed for the sole purpose of providing smoke control and that upon activation of the systems operate specifically to perform the smoke control function.

3.3.23.3* *Nondedicated Smoke Control Systems.* A smokecontrol system that shares components with some other system(s), such as the building HVAC system, which changes its mode of operation to achieve the smoke-control objective. [1, 2018]

3.3.23.4 Pressurization System.

3.3.23.4.1 *Multiple-Injection Pressurization System.* A type of smoke control system that has pressurization air supplied from multiple locations.

3.3.23.4.2 *Single-Injection Pressurization System.* A type of containment smoke control system that has pressurization air supplied from only one location.

3.3.23.5 *Smoke Control System.* An engineered system that includes all methods that can be used singly or in combination to modify smoke movement.

3.3.23.6* *Smoke Exhaust System.* A mechanical or gravity system intended to move smoke from the smoke zone to the exterior of the building, including smoke removal, purging, and venting systems, as well as the function of exhaust fans utilized to reduce the pressure in a smoke zone.

3.3.23.7 *Zoned Smoke Control System.* A smoke control system that includes a combination of smoke containment and smoke management methods for smoke exhaust for the smoke zone and pressurization for all contiguous smoke control zones.

2018 Edition

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.

3.3.24* Tenable Environment. An environment in which smoke and heat are limited or otherwise restricted to maintain the impact on occupants to a level that is not life threatening.

3.3.25 Zone.

3.3.25.1 Smoke Control Zone. A space within a building enclosed by smoke barriers, including the top and bottom, that is part of a zoned smoke control system.

3.3.25.2 Smoke Zone. The smoke control zone in which the fire is located.

3.3.25.3* Transition Zone. The layer between the smoke layer interface and the first indication of smoke in which the smoke layer temperature decreases to ambient.

Chapter 4 Design Fundamentals

4.1 Design Objectives.

4.1.1* The methods for accomplishing smoke control shall include one or more of the following:

- The containment of smoke to the zone of origin by estab-(1)lishment and maintenance of pressure differences across smoke zone boundaries
- (2)The management of smoke within a large-volume space and any unseparated spaces that communicate with the large-volume space

4.1.2* The specific objectives to be achieved over the design interval time shall include one or more of the following:

- Containing the smoke to the zone of fire origin (1)
- (2)Maintaining a tenable environment within exit stairwells for the time necessary to allow occupants to exit the building
- (3) Maintaining a tenable environment within all exit access and smoke refuge area access paths for the time necessary to allow occupants to reach an exit or smoke refuge area
- (4)Maintaining the smoke layer interface to a predetermined elevation in large volume spaces

4.2 Design Basis.

4.2.1* Smoke Containment Systems. A smoke control system in a given building shall be designed to contain smoke to a given zone or keep smoke from entering another zone.

4.2.1.1 The design pressure difference shall be based on the following:

- (1)Whether the smoke zone is sprinklered
- (2)The height of the ceiling in the smoke zone
- Maximum and minimum pressure differentials (3)

4.2.2 Smoke Management Systems. The design basis for smoke management within a given large-volume space and any unseparated spaces shall include the determination of the following parameters:

- The design basis fires used to calculate smoke production (1)(i.e., type, location, and quantity of fuel for each design basis fire, extent of coverage and reliability of automatic suppression, and extent and type of ventilation)
- (2) Height, cross-sectional area, and plan area of the largevolume space to be protected

- Height, cross-sectional area, and plan area of each unse-(3)parated space that communicates with the large-volume space
- Type and location of occupancies within and communi-(4)cating with the large-volume space
- (5)Barriers, if any, that separate the communicating space from the large-volume space
- Egress routes from the large-volume space and any (6)communicating space
- Any areas of refuge (7)

4.2.3 Temperature Ratings.

4.2.3.1 The temperature ratings for the equipment used for smoke control systems shall be based on the expected temperature experienced by the equipment while the equipment is intended to be operational.

4.2.3.2 Temperature ratings shall be based on the following:

- (1)Proximity to the fire
- Effects of dilution of the smoke and hot gases by (2)entrained air

4.3 Design Approaches.

4.3.1 Smoke Containment Systems. The design approach for smoke containment systems shall be one of or a combination of the following:

- Stairwell pressurization (1)
- (2)Zoned smoke control
- Elevator pressurization (3)
- (4)Vestibule pressurization
- Smoke refuge area pressurization (5)

4.3.2* Smoke Management Systems. The design approach for smoke management within large-volume spaces and communicating spaces shall be one of or a combination of the following:

- Natural smoke filling of an unoccupied volume or smoke (1)reservoir and calculating or modeling of smoke layer descent to determine whether the smoke layer interface will reach a height at which occupants will be exposed to smoke prior to their ability to egress from the space
- $(2)^{*}$ Mechanical smoke exhaust capacity to remove smoke from a space to maintain the smoke layer interface at a predefined height in the space for the design interval time
- (3)Mechanical smoke exhaust capacity to remove smoke from a space to slow the rate of smoke layer descent for a period that allows occupants to safely egress from the space
- (4)Gravity smoke venting to maintain the smoke layer interface at a predefined height in the space for the design interval time
- Gravity smoke venting to slow the rate of smoke layer (5)descent for a period that allows occupants to egress from the space
- (6)* Opposed airflow to prevent smoke movement between a large-volume space and a communicating space

4.4 Design Criteria.

4.4.1* Weather Data. Designs shall incorporate the effect of outdoor temperature and wind on the performance of systems.

4.4.2 Pressure Differences. The maximum and minimum allowable pressure differences across the boundaries of smoke control zones shall be established for containment systems.

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.

4.4.2.1 Pressure Differences Across Spaces.

4.4.2.1.1* Except as specified by 4.4.2.1.2, the pressure differences in Table 4.4.2.1.1 shall be used for designs that are based on maintaining minimum pressure differences between specified spaces.

4.4.2.1.2 Where the system designer has determined that a higher minimum pressure difference is necessary to achieve the smoke control system objectives, the higher minimum pressure difference shall be used.

4.4.2.1.3 The minimum allowable pressure difference shall restrict smoke leakage during building evacuation to a level that maintains a tenable environment in areas outside the smoke zone.

4.4.2.1.4 The minimum pressure difference for smoke control systems shall be established at a level that is high enough that it will not be overcome by the forces of wind, stack effect, or buoyancy of hot smoke.

4.4.2.1.5 The calculations shall take into account the design number of doors to be opened simultaneously.

4.4.2.2* Pressure Differences Across Doors. The pressure differences across doors shall not cause the maximum force permitted to begin opening the door to exceed the value stipulated in NFPA *101* or state or local codes and regulations.

4.4.3 Fire Location. The source of the smoke from the design basis fires shall consider fire locations within the large-volume space and within unseparated communicating spaces.

4.4.4 Smoke Movement and Airflow.

4.4.4.1* Makeup Air. Makeup air for smoke management systems shall be provided by fans or by openings to the outside.

4.4.4.1.1 The supply points for the makeup air shall be located beneath the smoke layer interface.

4.4.4.1.2 Mechanical makeup air shall be less than the mass flow rate of the mechanical smoke exhaust.

Building Type	Ceiling Height (ft)	Design Pressure Difference* (in. w.g.)
AS	Any	0.05
NS	9	0.10
NS	15	0.14
NS	21	0.18

For SI units, 1 ft = 0.305 m; 0.1 in. w.g. = 25 Pa. AS: Sprinklered. NS: Nonsprinklered.

(1) The table presents minimum design pressure differences

developed for a gas temperature of 1700° F (927°C) next to the smoke barrier.

(2) For design purposes, a smoke control system must maintain these minimum pressure differences under specified design conditions of stack effect or wind.

*For zoned smoke control systems, the pressure difference is required to be measured between the smoke zone and adjacent spaces while the affected areas are in the smoke control mode. **4.4.4.1.3** The makeup air shall not cause door-opening force to exceed allowable limits.

4.4.4.1.4* The makeup air velocity shall not exceed 200 ft/min (1.02 m/sec) where the makeup air could come into contact with the plume unless a higher makeup air velocity is supported by engineering analysis.

4.4.4.2 Communicating Spaces.

4.4.4.2.1 Managing Smoke Spread to Communicating Spaces.

4.4.4.2.1.1 Managing smoke spread to communicating spaces shall be accomplished by one of the following methods:

- (1) Maintaining the smoke layer interface at a level higher than that of the highest opening to the communicating space
- (2) Providing a smoke barrier to limit smoke spread into the communicating space
- (3) Providing an opposed airflow through the opening to prohibit smoke spread into the communicating space

4.4.4.2.1.2 When smoke barriers are used to limit smoke spread into the communicating space, engineering calculations shall be provided to verify whether a pressure difference applied across the smoke barrier will be needed to prevent smoke migration.

4.4.4.2.1.3 When the airflow method is used to prevent smoke movement from the large-volume space into communicating spaces for large openings, the flow shall be nearly perpendicular to the plane of the opening.

4.4.4.2.2* Managing Smoke from Communicating Spaces.

4.4.4.2.2.1 When communicating spaces are designed to allow the smoke to spill into the large-volume space, the smoke spilling into the large-volume space shall be handled by the smoke management system to maintain the design smoke layer interface height.

4.4.4.2.2.2 When the smoke control systems are designed to use airflow to prevent the movement of smoke into the large-volume space, sufficient exhaust from the communicating space shall be provided to establish a minimum flow between the communicating space and the large-volume space. (See 5.10.1.)

4.4.4.3* Openings and Leakage Areas. Designs shall incorporate the effect of openings and leakage areas in smoke barriers on the performance of smoke control systems.

4.4.4.4 Special Considerations Related to Natural Venting. Smoke management system designs that use a mix of natural and mechanical ventilation shall have supporting engineering analysis or physical (scale) modeling to verify the design functions as intended.

4.4.5* Gaseous Fire Suppression Systems. The operation of the smoke control system shall not compromise the performance of gaseous agent fire protection systems.

4.5* System Operation.

4.5.1 Limitations.

4.5.1.1* Tenability. Where the design of the smoke control system is based on the potential for occupants being exposed to smoke, the tenability conditions shall be assessed.

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.

Notes: