



---

# UL 67

## STANDARD FOR SAFETY

### Panelboards



UL Standard for Safety for Panelboards, UL 67

Thirteenth Edition, Dated May 15, 2018

**SUMMARY OF TOPICS:**

***This revision of ANSI/UL 67 dated July 31, 2020, includes the following changes in requirements:***

***Addition of New Requirements in Article 705 of the 2020 NEC to UL 67; [6.6.11](#), [6.6.12](#), [6.6.13](#), [31.2](#), [34.16.5](#), [34.16.7](#).***

***Correction to [Table 25.3](#)***

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated February 14, 2020.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

**MAY 15, 2018**  
(Title Page Reprinted: July 31, 2020)



**ANSI/UL 67-2020**

1

## **UL 67**

### **Standard for Panelboards**

First Edition – November, 1917  
Second Edition – July, 1928  
Third Edition – April, 1931  
Fourth Edition – March, 1941  
Fifth Edition – November, 1948  
Sixth Edition – May, 1965  
Seventh Edition – July, 1967  
Eighth Edition – August, 1974  
Ninth Edition – August, 1979  
Tenth Edition – October, 1988  
Eleventh Edition – December, 1993  
Twelfth Edition – March, 2009

### **Thirteenth Edition**

**May 15, 2018**

This ANSI/UL Standard for Safety consists of the Thirteenth Edition including revisions through July 31, 2020.

The most recent designation of ANSI/UL 67 as an American National Standard (ANSI) occurred on June 30, 2020. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

The Department of Defense (DoD) has adopted UL 67 on June 18, 1990. The publication of revised pages or a new edition of this Standard will not invalidate the DoD adoption.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

**COPYRIGHT © 2020 UNDERWRITERS LABORATORIES INC.**

This is a preview. Click here to purchase the full publication.

No Text on This Page

## CONTENTS

### INTRODUCTION

1	Scope .....	7
2	Components .....	7
3	Units of Measurement .....	9
4	Undated References .....	9
5	Glossary .....	9

### CONSTRUCTION

6	General .....	17
6.1	All panelboards .....	17
6.2	Equipment on supply side of disconnect .....	17
6.3	Distribution equipment .....	18
6.4	Service equipment .....	18
6.5	Branch circuits .....	20
6.6	Electrical connections .....	20
6.7	Field installable equipment .....	22
7	Enclosure .....	23
7.1	General .....	23
7.2	Component arrangement .....	24
7.3	Ventilating openings .....	24
8	Bases and Supports – Insulating Material .....	25
9	Covers, Barriers, and Partitions .....	27
9.1	General .....	27
9.2	Bushings .....	30
10	Filler Plates .....	30
11	Current-Carrying Parts .....	31
11.1	General .....	31
11.2	Bus bars, supports .....	33
11.3	Ampacity General .....	35
11.4	Main unit ratings .....	38
11.5	Neutral .....	39
11.6	Fuseholders and circuit breakers .....	40
12	Wiring Terminals .....	40
12.1	General .....	40
12.2	Screw terminals .....	42
13	Cord-Connectors .....	44
13.1	General .....	44
13.2	Input connections .....	44
13.3	Output connections .....	45
14	Switches, Circuit Breakers, and Overcurrent-Protective Devices .....	46
14.1	General .....	46
14.2	Ratings .....	47
14.3	Main and main-disconnect switches and circuit breakers .....	47
14.4	Switches .....	47
14.5	Overcurrent protective devices .....	48
14.6	Lighting and appliance panelboards .....	48
14.7	Fuseholders .....	48
14.8	Panelboards with integral inlet .....	49
15	Ground-Fault Protection .....	49
16	Spacings .....	51
16.1	General .....	51

16.2	Switches .....	55
16.3	Barriers and liners.....	55
16.4	Tape .....	57
16.5	Tubing .....	58
17	Wiring Space, Wiring Gutters, and Wire Bending Space .....	58
17.1	General.....	58
17.2	Wiring space, wiring gutters, and terminal compartments.....	62
17.3	Wire deflection and bending space.....	66
17.4	Determination of deflection and bending space distances .....	67
18	Grounding and Bonding .....	73
18.1	General.....	73
18.2	Equipment-grounding terminals .....	76
19	Sharp Edges.....	78
20	Separation of Circuits .....	78

## PERFORMANCE

21	Temperature Test .....	78
21.1	General.....	78
21.2	Main lug .....	81
21.3	Main circuit breaker.....	82
21.4	Neutral.....	82
21.5	Clamped joints .....	83
21.6	Other bus bar coatings .....	84
21.7	Joints with insulators .....	84
22	Rain Test .....	84
23	Strength of Insulating Base and Support Test .....	85
24	Mold Stress Relief Test .....	85
25	Short-Circuit Current Test.....	85
25.1	General.....	85
25.2	Sample selection .....	88
25.3	Sample preparation .....	89
25.4	Line connections.....	89
25.5	Load connections .....	93
25.6	Fuses .....	93
25.7	Meter mounting positions .....	95
25.8	Short-circuit procedure.....	95
25.9	Short-circuit tests.....	97
25.10	Evaluation of test results.....	98
26	Dielectric Voltage-Withstand Test .....	98
26.1	General .....	98
26.2	Joints with insulators.....	99
26.3	After short circuit.....	99
26.4	Insulating barriers .....	99
27	Bonding Resistance Test.....	100
28	Test Requirements for Panelboards Used as Transfer Equipment .....	100

## MANUFACTURING AND PRODUCTION TESTS

29	Ground-Fault Protection Test.....	100
----	-----------------------------------	-----

## RATING

30	General .....	101
31	Current.....	101



32	Voltage .....	102
33	Short Circuit Current – Details .....	103

## MARKING

34	Details .....	103
34.1	General .....	103
34.2	Wiring space and terminals .....	107
34.3	Field-installed conductors .....	108
34.4	Arrangement of terminals .....	109
34.5	Tightening torque .....	109
34.6	Enclosure type marking .....	112
34.7	Switches and circuit breakers .....	112
34.8	Lighting and appliance panelboards .....	113
34.9	Service equipment .....	113
34.10	Ground-fault protection .....	114
34.11	Distribution equipment .....	115
34.12	Field-installed equipment .....	115
34.13	Equipment-grounding terminals .....	117
34.14	Filler plates .....	118
34.15	Neutral .....	119
34.16	Parallel Power Source Panelboard .....	119
34.17	Panelboard with connection to Uninterruptible Power Supply .....	120
34.18	Panelboard with provisions for cord connections .....	120
35	Permanence of Marking .....	120

## INSTALLATION INSTRUCTIONS

36	Field Testing of Ground-Fault Protection of Equipment .....	121
----	---	-----

## SUPPLEMENT SA – PANELBOARDS FOR USE UNDER USCG ELECTRICAL ENGINEERING REGULATIONS SUBCHAPTER J (46 CFR, PARTS 110 – 113)

### PANELBOARDS FOR MARINE USE

SA1	Scope .....	123
SA2	Enclosure .....	123
SA3	Current-Carrying Parts .....	124
SA4	Switches, Circuit Breakers, and Overcurrent Protection .....	124
SA5	Insulating Material .....	124
SA6	Marking .....	124

## SUPPLEMENT SB – CLASSIFIED CIRCUIT BREAKERS FOR USE WITH SPECIFIED PANELBOARDS AS AN ALTERNATE FOR SPECIFIED CIRCUIT BREAKERS

### INTRODUCTION

SB1	Scope .....	125
SB2	Glossary .....	125

### CONSTRUCTION

SB3	General .....	125
-----	---------------	-----

**PERFORMANCE**

SB4	General.....	125
SB5	Insertion and Withdrawal Test.....	126
SB6	Temperature Test.....	126
SB7	Short-Circuit Current Test.....	126

**MARKING**

SB8	Details .....	127
-----	---------------	-----

**SUPPLEMENT SC – CLASSIFIED MOLDED-CASE SURGE PROTECTIVE DEVICES (SPDs) FOR USE WITH SPECIFIED PANELBOARDS****INTRODUCTION**

SC1	Scope.....	129
SC2	Glossary .....	129

**CONSTRUCTION**

SC3	General .....	129
-----	---------------	-----

**PERFORMANCE**

SC4	General .....	130
SC5	Insertion and Withdrawal Test.....	130

**MARKING**

SC6	Details .....	130
-----	---------------	-----

**APPENDIX A Standards for Components****Appendix B (Informative) Explanatory Information Regarding Wire Deflection And Bending Distances**

## INTRODUCTION

### 1 Scope

1.1 These requirements cover panelboards to be employed in accordance with the National Electrical Code, NFPA 70.

1.2 These requirements cover panelboards for the control and protection electrical circuits.

1.3 These requirements do not cover:

- a) Distribution equipment which sole function is the automatic or nonautomatic transferring of one or more load conductor connections from one power source to another. Reference the Standard for Transfer Switch Equipment, UL 1008.
- b) Factory wired assemblies of industrial control equipment intended to control industrial processes. Reference the Standard for Industrial Control Panels, UL 508A.
- c) Distribution equipment containing only one circuit subdivision, unless also provided with a meter socket. See [6.5.1](#). Reference the Standard for Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures, UL 489.
- d) Distribution equipment intended to serve as a means for distributing power required to operate mobile or temporarily installed equipment. Reference the Standard for Power Outlets, UL 231.
- e) Factory wired assemblies of controllers, timers, temperature regulating equipment and such, intended for control of equipment for use with swimming pools, hot tubs, and/or spas. Reference the Standard for Electric Spas, Equipment Assemblies, and Associated Equipment, UL 1563.
- f) Factory wired assemblies intended for the control of Architectural and Floating Fountains. Reference the Standards for Motor-Operated Water Pumps, UL 778, Underwater Luminaires and Submersible Junction Boxes, UL 676 and Industrial Control Panels, UL 508A.
- g) Portable power distribution equipment. Reference the Standard for Portable Power-Distribution Equipment, UL 1640.
- h) Panelboards with converter and/or inverter functions, intended for use as distribution equipment in recreational vehicles. Reference the Standard for Power Converters/Inverters and Power Converter/Inverter Systems for Land Vehicles and Marine Crafts, UL 458.

### 2 Components

2.1 Except as indicated in [2.2](#), a component of a product covered by this standard shall comply with the requirements for that component. See Appendix [A](#) for a list of standards covering components generally used in the products covered by this standard.

2.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.3 A component shall be used in accordance with its rating established for the intended conditions of use.